

Client: ADMASTON PUBLIC SCHOOL  
182 Stone Rd.  
Renfrew, ON  
K7V 3Z5  
Attention: Ms. Paula Vanhoof  
PO#: 6071346759  
Invoice to: Renfrew County District School Board

Report Number: 1602104  
Date Submitted: 2016-02-10  
Date Reported: 2016-03-01  
Project: Admaston PS  
COC #: 805414  
Waterworks/Facility: 260013767

Page 1 of 4

---

**Dear Paula Vanhoof:**

**Please find attached the analytical results for your samples. If you have any questions regarding this report, please do not hesitate to call (613-727-5692).**

Report Comments:



Shyla Monette  
2016.03.01 12:44:26 -05'00'

APPROVAL: \_\_\_\_\_

Shyla Monette  
Team Leader, Inorganics



Charlie  
(Long) Qu  
2016.03.0  
1 11:21:32  
-05'00'

APPROVAL: \_\_\_\_\_

Charlie (Long) Qu  
Laboratory Supervisor, Organics

All analysis is completed in Ottawa, Ontario (unless otherwise indicated).

Exova Ottawa is accredited by CALA, Canadian Association for Laboratory Accreditation to ISO/IEC 17025 for tests which appear on our CALA scope of accreditation. It can be found at <http://www.cala.ca/scopes/2602.pdf>.

Exova (Ottawa) is certified and accredited for specific parameters by OMAFRA, Ontario Ministry of Agriculture, Food and Rural Affairs (for farm soils). Licensed by Ontario MOE for specific tests in drinking water.

Exova (Mississauga) is accredited for specific parameters by SCC, Standards Council of Canada (to ISO 17025)

Please note: Field data, where presented on the report, has been provided by the client and is presented for informational purposes only. Guideline values listed on this report are provided for ease of use (informational purposes) only. Exova recommends consulting the official provincial or federal guideline as required.

Client: ADMASTON PUBLIC SCHOOL  
 182 Stone Rd.  
 Renfrew, ON  
 K7V 3Z5  
 Attention: Ms. Paula Vanhoof  
 PO#: 6071346759  
 Invoice to: Renfrew County District School Board

Report Number: 1602104  
 Date Submitted: 2016-02-10  
 Date Reported: 2016-03-01  
 Project: Admaston PS  
 COC #: 805414  
 Waterworks/Facility: 260013767

Group	Analyte	MRL	Units	Guideline	Lab I.D. Sample Matrix Sample Type Sampling Date Sample I.D.
Herbicide/Pesticide	2,3,4,6-tetrachlorophenol	0.5	ug/L	MAC-100	1226474 Supply Water TREATEDWATER 2016-02-09 Admaston PS
	2,4,6-trichlorophenol	0.5	ug/L	MAC-5	<0.5
	2,4-dichlorophenol	0.5	ug/L	MAC-900	<0.5
	2,4-dichlorophenoxyacetic acid (2,4-D)	1.0	ug/L	IMAC-100	<1.0
	a-chlordane	0.006	ug/L		<0.006
	Alachlor	0.5	ug/L	IMAC-5	<0.5
	Aldrin	0.006	ug/L		<0.006
	Atrazine	1.0	ug/L		<1.0
	Atrazine + N-dealkylated metabolites	0.2	ug/L	IMAC-5	<0.2
	Azinphos-methyl	2.0	ug/L	MAC-20	<2.0
	Bendiocarb	2.0	ug/L	MAC-40	<2.0
	Benzo(a)pyrene	0.01	ug/L	MAC-0.01	<0.01
	Bromoxynil	0.5	ug/L	IMAC-5	<0.5
	Carbaryl	5.0	ug/L	MAC-90	<5.0
	Carbofuran	5.0	ug/L	MAC-90	<5.0
	Chlorpyrifos	1.0	ug/L	MAC-90	<1.0
	De-ethylated atrazine	1.0	ug/L		<1.0
	Diazinon	1.0	ug/L	MAC-20	<1.0
	Dicamba	1.0	ug/L	MAC-120	<1.0
	Diclofop-methyl	0.9	ug/L	MAC-9	<0.9
Dieldrin	0.006	ug/L		<0.006	
Dimethoate	2.5	ug/L	IMAC-20	<2.5	
Diquat	5	ug/L	MAC-70	<5	
Diuron	10	ug/L	MAC-150	<10	
g-chlordane	0.006	ug/L		<0.006	
Glyphosate	10	ug/L	IMAC-280	<10	

**Guideline = MOE REG. 170/03**

**\* = Guideline Exceedence**

All analysis completed in Ottawa, Ontario (unless otherwise indicated by \*\* which indicates analysis was completed in Mississauga, Ontario).

Results relate only to the parameters tested on the samples submitted.

Methods references and/or additional QA/QC information available on request.

MRL = Method Reporting Limit, AO = Aesthetic Objective, OG = Operational Guideline, MAC = Maximum Acceptable Concentration, IMAC = Interim Maximum Acceptable Concentration, STD = Standard, PWQO = Provincial Water Quality Guideline, IPWQO = Interim Provincial Water Quality Objective, TDR = Typical Desired Range

Client: ADMASTON PUBLIC SCHOOL  
 182 Stone Rd.  
 Renfrew, ON  
 K7V 3Z5  
 Attention: Ms. Paula Vanhoof  
 PO#: 6071346759  
 Invoice to: Renfrew County District School Board

Report Number: 1602104  
 Date Submitted: 2016-02-10  
 Date Reported: 2016-03-01  
 Project: Admaston PS  
 COC #: 805414  
 Waterworks/Facility: 260013767

Lab I.D.  
 Sample Matrix  
 Sample Type  
 Sampling Date  
 Sample I.D.

1226474  
 Supply Water  
 TREATEDWATER  
 2016-02-09  
 Admaston PS

Group	Analyte	MRL	Units	Guideline	
Herbicide/Pesticide	Malathion	5.0	ug/L	MAC-190	<5.0
	MCPA	10	ug/L		<10
	Metolachlor	1.0	ug/L	IMAC-50	<1.0
	Metribuzin	5.0	ug/L	MAC-80	<5.0
	op-DDT	0.006	ug/L		<0.006
	Oxychlorane	0.006	ug/L		<0.006
	Paraquat	1	ug/L	IMAC-10	<1
	Pentachlorophenol	0.5	ug/L	MAC-60	<0.5
	Phorate	0.5	ug/L	IMAC-2	<0.5
	Picloram	5.0	ug/L	IMAC-190	<5.0
	pp-DDD	0.006	ug/L		<0.006
	pp-DDE	0.006	ug/L		<0.006
	pp-DDT	0.006	ug/L		<0.006
	Prometryne	0.25	ug/L	IMAC-1	<0.25
	Simazine	1.0	ug/L	IMAC-10	<1.0
	Terbufos	0.4	ug/L	IMAC-1	<0.4
	Triallate	1	ug/L	MAC-230	<1
Trifluralin	1.0	ug/L	IMAC-45	<1.0	
Mercury	Mercury	0.0001	mg/L	MAC-0.001	<0.0001
Metals	Antimony	0.0005	mg/L	IMAC-0.006	<0.0005
	Arsenic	0.001	mg/L	IMAC-0.025	<0.001
	Barium	0.01	mg/L	MAC-1.0	<0.01
	Boron	0.01	mg/L	IMAC-5.0	0.08
	Cadmium	0.0001	mg/L	MAC-0.005	<0.0001
	Chromium	0.001	mg/L	MAC-0.05	<0.001
	Selenium	0.001	mg/L	MAC-0.01	<0.001

**Guideline = MOE REG. 170/03** \* = **Guideline Exceedence**  
 All analysis completed in Ottawa, Ontario (unless otherwise indicated by \*\* which indicates analysis was completed in Mississauga, Ontario).  
 Results relate only to the parameters tested on the samples submitted.  
 Methods references and/or additional QA/QC information available on request.

MRL = Method Reporting Limit, AO = Aesthetic Objective, OG = Operational Guideline, MAC = Maximum Acceptable Concentration, IMAC = Interim Maximum Acceptable Concentration, STD = Standard, PWQO = Provincial Water Quality Guideline, IPWQO = Interim Provincial Water Quality Objective, TDR = Typical Desired Range

Client: ADMASTON PUBLIC SCHOOL  
 182 Stone Rd.  
 Renfrew, ON  
 K7V 3Z5  
 Attention: Ms. Paula Vanhoof  
 PO#: 6071346759  
 Invoice to: Renfrew County District School Board

Report Number: 1602104  
 Date Submitted: 2016-02-10  
 Date Reported: 2016-03-01  
 Project: Admaston PS  
 COC #: 805414  
 Waterworks/Facility: 260013767

Lab I.D.	1226474
Sample Matrix	Supply Water
Sample Type	TREATEDWATER
Sampling Date	2016-02-09
Sample I.D.	Admaston PS

Group	Analyte	MRL	Units	Guideline	
Metals	Uranium	0.001	mg/L	MAC-0.02	0.004
PCBs	Polychlorinated Biphenyls (PCBs)	0.1	ug/L	IMAC-3	<0.1
VOCs	1,1-dichloroethylene	0.5	ug/L	MAC-14	<0.5
	1,2-dichlorobenzene	0.4	ug/L	MAC-200	<0.4
	1,2-dichloroethane	0.2	ug/L	IMAC-5	<0.2
	1,4-dichlorobenzene	0.4	ug/L	MAC-5	<0.4
	Benzene	0.5	ug/L	MAC-5	<0.5
	Carbon Tetrachloride	0.2	ug/L	MAC-5	<0.2
	Dichloromethane	4.0	ug/L	MAC-50	<4.0
	Monochlorobenzene	0.2	ug/L	MAC-80	<0.2
	Tetrachloroethylene	0.3	ug/L	MAC-30	<0.3
	Trichloroethylene	0.3	ug/L	MAC-5	<0.3
	Vinyl Chloride	0.2	ug/L	MAC-2	<0.2
VOCs Surrogates (%REC)	1,2-dichloroethane-d4	0	%		124
	4-bromofluorobenzene	0	%		127
	Toluene-d8	0	%		96

**Guideline = MOE REG. 170/03**      \* = **Guideline Exceedence**

All analysis completed in Ottawa, Ontario (unless otherwise indicated by \*\* which indicates analysis was completed in Mississauga, Ontario).  
 Results relate only to the parameters tested on the samples submitted.  
 Methods references and/or additional QA/QC information available on request.

MRL = Method Reporting Limit, AO = Aesthetic Objective, OG = Operational Guideline, MAC = Maximum Acceptable Concentration, IMAC = Interim Maximum Acceptable Concentration, STD = Standard, PWQO = Provincial Water Quality Guideline, IPWQO = Interim Provincial Water Quality Objective, TDR = Typical Desired Range