

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
ADHS	06-Jun-17	Flush	06-Jun-17								
Day 1	07-Jun-17	L. Riopelle	6:00	S	5:00	Main Office sink Tap 1	S	2.0	30-Jun-17		
				F	5:53	Main Office sink Tap 1	F	<0.001	30-Jun-17		
	07-Jun-17	L. Riopelle	6:01	S	5:01	Upper Library sink	S	59.0	30-Jun-17	Out of Service, Investigate	Tap capped off Sep 15/17
				F	5:54	Upper Library sink	F	31.0	30-Jun-17		Out of Service - NFA
	07-Jun-17	L. Riopelle	6:02	S	5:02	Rm 107 Kitchen Tap 1	S	36.0	30-Jun-17	Daily Flushing	Daily Flushing of Tap
				F	5:54	Rm 107 Kitchen Tap 1	F	9.0	30-Jun-17		
	07-Jun-17	L. Riopelle	6:03	S	5:03	Rm 108 Filter Tap 1	S	2.0	30-Jun-17		
				F	5:55	Rm 108 Filter Tap 1	F	2.0	30-Jun-17		
	07-Jun-17	L. Riopelle	6:03	S	5:03	Custodial Office sink	S	2.0	30-Jun-17		
				F	5:55	Custodial Office sink	F	1.0	30-Jun-17		
	07-Jun-17	L. Riopelle	6:06	S	5:06	Cafeteria Kitchen Tap 1 (below clock)	S	6.0	30-Jun-17		
				F	5:58	Cafeteria Kitchen Tap 1	F	2.0	30-Jun-17		
Day 2 - ADHS	13-Jun-17	Flushed	13-Jun-17								
	14-Jun-17	L. Riopelle	6:07	S	5:02	Main Office Filtered Tap 2	F	<0.001	30-Jun-17		
				F	5:52	Main Office Filtered Tap 2	F	<0.001	30-Jun-17		
	14-Jun-17	L. Riopelle	6:10	S	5:05	Rm 107 Filtered Tap 2	S	<0.001	30-Jun-17		
				F	5:55	Rm 107 Filtered Tap 2	F	<0.001	30-Jun-17		
	14-Jun-17	L. Riopelle	6:08	S	5:03	Custodial Office Filter Tap 2	S	<0.001	6-Jul-17		
				F	5:53	Custodial Office Filter Tap 2	F	<0.001	6-Jul-17		
Day 3 - ADHS	20-Jun-17	Flushed	20-Jun								
	21-Jun-17	L. Riopelle	6:10	S	5:05	Caf Kitchen Tap 3	S	16.0	9-Jul-17	Daily Flushing	Daily Flushing of Tap
				F	5:57	Caf Kitchen Tap 3	F	5.0	9-Jul-17		
	21-Jun-17	L. Riopelle	6:16	S	5:11	Caf Kitchen Tap 4 by Freezer	S	4.0	10-Jul-17		
				F	6:03	Caf Kitchen Tap 4 by Freezer	F	<0.001	10-Jul-17		
Day 4 - ADHS	19-Sep-17		19-Sep								
	20-Sep-17	L. Riopelle	6:00	S	4:55	Rm 108 Tap 2 Front Counter	S	2.0	3-Oct-17		
				F	5:48	Rm 108 Tap 2 Front Counter	F	1.0	3-Oct-17		
	20-Sep-17	L. Riopelle	6:02	S	4:57	Fill Station Fountain by Weight Rm	S	<0.001	3-Oct-17		
				F	5:49	Fill Station Fountain by Weight Rm	F	<0.001	3-Oct-17		
	20-Sep-17	L. Riopelle	6:04	S	4:59	FS Hall Fountain by Rm 111	S	<0.001	3-Oct-17		
				F	5:51	FS Hall Fountain by Rm 111	F	<0.001	3-Oct-17		
	20-Sep-17	L. Riopelle	6:06	S	5:01	2nd Flr Fountain by Rm 215	S	<0.001	3-Oct-17		
				F	5:52	2nd Flr Fountain by Rm 215	F	<0.001	3-Oct-17		
Day 5 - ADHS	26-Sep-17	Flush	26-Sep								
	27-Sep-17	L. Riopelle	6:01	S	4:56	Fill Station Fountain by Rm 119	S	<0.001	3-Oct-17		
				F	5:47	Fill Station Fountain by Rm 119	F	<0.001	3-Oct-17		
	27-Sep-17	L. Riopelle	6:03	S	4:58	Caf Kitchen Tap 2 Filtered	S	2.0	3-Oct-17		
				F	5:49	Caf Kitchen Tap 2 Filtered	F	<0.001	3-Oct-17		
	27-Sep-17	L. Riopelle	6:06	S	5:01	Tech Hall FS Fountain	S	<0.001	3-Oct-17		
				F	5:51	Tech Hall FS Fountain	F	<0.001	3-Oct-17		
ADHS - Floor 1 complete											
Admaston	05-Jun-17	Flush	05-Jun-17								
Day 1	06-Jun-17	Flush	06-Jun-17								
	07-Jun-17	P. Bromley	6:44	S	4:29	Rm 1 Fountain	S	12.0	30-Jun-17	Daily Flush Fountain	Daily Flush Fountain
				F	5:32	Rm 1 Fountain	F	1.0	30-Jun-17		
	07-Jun-17	P. Bromley	6:46	S	4:31	Rm 2 Fountain	S	<0.001	5-Jul-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
				F	5:33	Rm 2 Fountain	F	<0.001	5-Jul-17		
	07-Jun-17	P. Bromley	6:48	S	4:33	Rm 3 Fountain	S	1.0	5-Jul-17		
				F	5:35	Rm 3 Fountain	F	<0.001	5-Jul-17		
	07-Jun-17	P. Bromley	6:50	S	4:35	Rm 4 Fountain	S	1.0	5-Jul-17		
				F	5:37	Rm 4 Fountain	F	<0.001	5-Jul-17		
	07-Jun-17	P. Bromley	6:52	S	4:37	Rm 5 Fountain	S	2.0	5-Jul-17		
				F	5:39	Rm 5 Fountain	F	<0.001	5-Jul-17		
	07-Jun-17	P. Bromley	6:54	S	4:39	Rm 6 Fountain	S	2.0	5-Jul-17		
				F	5:41	Rm 6 Fountain	F	2.0	5-Jul-17		
	07-Jun-17	P. Bromley	6:56	S	4:41	Rm 7 Fountain	S	<0.001	5-Jul-17		
				S	5:43	Rm 7 Fountain	S	<0.001	5-Jul-17		
	07-Jun-17	P. Bromley	6:58	S	4:43	Kitchen Wall Tap	S	1.0	5-Jul-17		
				F	5:44	Kitchen Wall Tap	F	<0.001	5-Jul-17		
	07-Jun-17	P. Bromley	7:00	S	4:45	Rm 9 Rt Tap	S	2.0	5-Jul-17		
				F	5:46	Rm 9 Rt Tap	F	1.0	5-Jul-17		
Day 2	07-Jun-17	Flush	07-Jun-17								
Admaston	08-Jun-17	P. Bromley	8:46	S	4:31	Rm 2 Tap	S	<0.001	5-Jul-17		
				F	5:30	Rm 2 Tap	F	<0.001	5-Jul-17		
	08-Jun-17	P. Bromley	8:47	S	4:32	Rm 3 Tap	S	<0.001	5-Jul-17		
				F	5:31	Rm 3 Tap	F	<0.001	5-Jul-17		
	08-Jun-17	P. Bromley	8:48	S	4:33	Rm 4 Tap	S	<0.001	5-Jul-17		
				F	5:32	Rm 4 Tap	F	<0.001	5-Jul-17		
	08-Jun-17	P. Bromley	8:49	S	4:34	Rm 5 Tap	S	1.0	5-Jul-17		
				F	5:33	Rm 5 Tap	F	<0.001	5-Jul-17		
	08-Jun-17	P. Bromley	8:50	S	4:35	Rm 6 Tap	S	2.0	5-Jul-17		
				F	5:34	Rm 6 Tap	F	3.0	5-Jul-17		
	08-Jun-17	P. Bromley	8:51	S	4:36	Rm 7 Tap	S	<0.001	5-Jul-17		
				F	5:35	Rm 7 Tap	F	<0.001	5-Jul-17		
	08-Jun-17	P. Bromley	8:53	S	4:38	Kitchen Island	S	4.0	5-Jul-17		
				S	5:37	Kitchen Island	S	2.0	5-Jul-17		
	08-Jun-17	P. Bromley	8:54	S	4:39	Rm 9 Left Tap	S	2.0	5-Jul-17		
				F	5:38	Rm 9 Left Tap	F	1.0	5-Jul-17		
Day 3	08-Jun-17	Flush	08-Jun-17								
Admaston	09-Jun-17	P. Bromley	8:14	S	6:05	Staff Room	S	5.0	6-Jul-17		
				F	6:55	Staff Room	F	6.0	6-Jul-17		
	09-Jun-17	P. Bromley	8:17	S	6:08	Rm 9 Right Fountain	S	8.0	6-Jul-17		
				F	6:58	Rm 9 Right Fountain	F	5.0	6-Jul-17		
Day 4	12-Jun-17	Flush	12-Jun-17								
Admaston	13-Jun-17	P. Bromley	8:41	S	6:15	Room 9 Left Fountain	S	11.0	4-Jul-17	Daily Flushing	Daily Flush Fountain
				F	7:02	Room 9 Left Fountain	F	5.0	4-Jul-17		
Day 5	14-Jun-17	Flush	14-Jun-17								
Admaston	15-Jun-17	P. Bromley	8:01	S	5:35	Hall 105 Fountain	S	<0.001	6-Jul-17		
				F	6:26	Hall 105 Fountain	F	<0.001	6-Jul-17		
	15-Jun-17	P. Bromley	8:03	S	5:37	Hall 127 Fountain	S	<0.001	6-Jul-17		
				F	6:24	Hall 127 Fountain	F	<0.001	6-Jul-17		
Day 6	25-Sep-17	Flush	25-Sep-17								
Admaston	26-Sep-17	P. Bromley	7:50	S	5:25	Room 1 tap	S	2.0	3-Oct-17		
				F	6:11	Room 1 tap	F	1.0	3-Oct-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
Admaston-Sampling Complete											
							F				
A.J. Charbonneau	05-Jun-17	Flush	05-Jun-17								
Day 1	06-Jun-17	D. Verdon	6:03	S	5:03	Rm 120 sink	S	<0.001	27-Jun-17		
		D. Verdon		F	5:55	Rm 120 sink	F	<0.001	27-Jun-17		
	06-Jun-17	D. Verdon	6:04	S	5:04	Rm 122 sink	S	<0.001	27-Jun-17		
		D. Verdon		F	5:56	Rm 122 sink	F	<0.001	27-Jun-17		
	06-Jun-17	D. Verdon	6:06	S	5:06	Rm 124 sink	S	<0.001	27-Jun-17		
		D. Verdon		F	5:57	Rm 124 sink	F	<0.001	27-Jun-17		
	06-Jun-17	D. Verdon	6:00	S	5:00	Rm 117 sink	S	<0.001	27-Jun-17		
		D. Verdon		F	5:53	Rm 117 sink	F	<0.001	27-Jun-17		
	06-Jun-17	D. Verdon	6:02	S	5:02	Rm 119 sink	S	1.0	27-Jun-17		
		D. Verdon		F	5:54	Rm 119 sink	F	<0.001	27-Jun-17		
A.J. Charbonneau	06-Jun-17	Flush	06-Jun-17								
Day 2	07-Jun-17	D. Verdon	6:05	S	5:05	Rm 118 sink	S	2.0	27-Jun-17		
		D. Verdon		F	6:00	Rm 118 sink	F	<0.001	27-Jun-17		
	07-Jun-17	D. Verdon	6:06	S	5:06	Rm 120 fountain	S	<0.001	27-Jun-17		
		D. Verdon		F	6:01	Rm 120 fountain	F	<0.001	27-Jun-17		
	07-Jun-17	D. Verdon	6:09	S	5:09	Rm 123 sink	S	<0.001	27-Jun-17		
		D. Verdon		F	6:03	Rm 123 sink	F	<0.001	27-Jun-17		
	07-Jun-17	D. Verdon	6:11	S	5:11	Rm 124 Fountain	S	<0.001	27-Jun-17		
		D. Verdon		F	6:04	Rm 124 Fountain	F	<0.001	27-Jun-17		
	07-Jun-17	D. Verdon	6:12	S	5:12	Rm 127 - Tap 1	S	2.0	27-Jun-17		
		D. Verdon		F	6:05	Rm 127 - Tap 1	F	<0.001	27-Jun-17		
A.J. Charbonneau	14-Jun-17	Flush	14-Jun-17								
Day 3	15-Jun-17	D. Verdon	6:08	S	5:08	Rm 118 Fountain	S	3.0	27-Jun-17		
		D. Verdon		F	6:03	Rm 118 Fountain	F	<0.001	27-Jun-17		
	15-Jun-17	D. Verdon	6:11	S	5:11	Rm 122 Fountain	S	<0.001	27-Jun-17		
		D. Verdon		F	6:06	Rm 122 Fountain	F	<0.001	27-Jun-17		
	15-Jun-17	D. Verdon	6:10	S	5:10	Rm 119 Fountain	S	<0.001	27-Jun-17		
		D. Verdon		F	6:04	Rm 119 Fountain	F	<0.001	27-Jun-17		
	15-Jun-17	D. Verdon	6:13	S	5:13	Rm 123 Fountain	S	<0.001	27-Jun-17		
		D. Verdon		F	6:07	Rm 123 Fountain	F	<0.001	27-Jun-17		
	15-Jun-17	D. Verdon	6:15	S	5:15	Kitchen Rm 127 Tap 2	S	<0.001	27-Jun-17		
		D. Verdon		F	6:08	Kitchen Rm 127 Tap 2	F	<0.001	27-Jun-17		
A.J. Charbonneau	15-Jun-17	Flush	15-Jun-17								
Day 4	16-Jun-17	D. Verdon	6:15	S	5:15	Rm 108 Custodial	S	<0.001	27-Jun-17		
		D. Verdon		F	6:05	Rm 108 Custodial	F	<0.001	27-Jun-17		
	16-Jun-17	D. Verdon	6:16	S	5:16	Kitchen Rm 127 Tap 3	S	<0.001	27-Jun-17		
		D. Verdon		F	6:06	Kitchen Rm 127 Tap 3	F	<0.001	27-Jun-17		
	16-Jun-17	D. Verdon	6:18	S	5:18	Staff Rm Kitchen	S	<0.001	27-Jun-17		
		D. Verdon		F	6:08	Staff Rm Kitchen	F	<0.001	27-Jun-17		
AJ - 2/3 completed											
Beachburg		flush	8-Jun-17								
Day 1	09-Jun-17	Mike Moore	9:12	S	7:09	Staffroom 104	S	<0.001	27-Jun-17		
	09-Jun-17	Mike Moore		F	8:09	Staffroom 104	F	<0.001	27-Jun-17		
	09-Jun-17	Mike Moore	9:15	S	7:12	Kindergarten #106 - Tap 1	S	1.0	27-Jun-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
	09-Jun-17	Mike Moore		F	8:10	Kindergarten #106 - Tap 1	F	<0.001	27-Jun-17		
	09-Jun-17	Mike Moore	9:17	S	7:14	Rm 124, gr 3	S	2.0	27-Jun-17		
	09-Jun-17	Mike Moore		F	8:12	Rm 124, gr 3	F	<0.001	27-Jun-17		
	09-Jun-17	Mike Moore	9:17	S	7:14	Rm 114, Gr 2	S	2.0	27-Jun-17		
	09-Jun-17	Mike Moore		F	8:14	Rm 114, Gr 2	F	<0.001	27-Jun-17		
	09-Jun-17	Mike Moore	9:22	S	7:19	Kitchen, 109B - Tap 1	S	3.0	27-Jun-17		
	09-Jun-17	Mike Moore		F	8:17	Kitchen, 109B - Tap 1	F	1.0	27-Jun-17		
	09-Jun-17	Mike Moore	9:25	S	7:22	Library, Rm 107	S	3.0	27-Jun-17		
	09-Jun-17	Mike Moore		F	8:19	Library, Rm 107	F	2.0	27-Jun-17		
Beachburg	13-Jun-17	Flush	13-Jun-17								
Day 2	14-Jun-17	Mike Moore	9:09	S	7:13	Kindergarten #106 - Tap 2	S	<0.001	27-Jun-17		
	14-Jun-17	Mike Moore		F	8:10	Kindergarten #106 - Tap 2	F	<0.001	27-Jun-17		
	14-Jun-17	Mike Moore	9:09	S	7:13	Kindergarten Rm 119	S	2.0	27-Jun-17		
	14-Jun-17	Mike Moore		F	8:09	Kindergarten Rm 119	F	<0.001	27-Jun-17		
	14-Jun-17	Mike Moore	9:14	S	7:18	Rm 120, Gr 1	S	5.0	30-Jun-17		
	14-Jun-17	Mike Moore		F	8:14	Rm 120, Gr 1	F	2.0	30-Jun-17		
	14-Jun-17	Mike Moore	9:16	S	7:20	Rm 114 Fountain	S	<0.001	27-Jun-17		
	14-Jun-17	Mike Moore		F	8:15	Rm 114 Fountain	F	<0.001	27-Jun-17		
	14-Jun-17	Mike Moore	9:20	S	7:23	Kitchen, 109B - Tap 2	S	4.0	27-Jun-17		
	14-Jun-17	Mike Moore		F	8:14	Kitchen, 109B - Tap 2	F	2.0	27-Jun-17		
Beachburg - Sampling Complete											
Central	26-Jun-17		26-Jun-17								
Day 1	27-Jun-17	L. Hisko	9:43	S	4:55	Kindergarten Rm 127 Tap 1	S	2.0	18-Jul-17		
				F	5:49	Kindergarten Rm 127 Tap 1	F	3.0	18-Jul-17		
	27-Jun-17	L. Hisko	9:44	S	4:56	Staff Rm 125 Tap 1	S	2.0	18-Jul-17		
				F	5:50	Staff Rm 125 Tap 1	F	<0.001	18-Jul-17		
	27-Jun-17	L. Hisko	9:46	S	4:58	Rm 205 Tap 1	S	1.0	18-Jul-17		
				F	5:51	Rm 205 Tap 1	F	<0.001	18-Jul-17		
	27-Jun-17	L. Hisko	9:47	S	4:59	Rm 206 Tap 1	S	2.0	18-Jul-17		
				F	5:52	Rm 206 Tap 1	F	<0.001	18-Jul-17		
	27-Jun-17	L. Hisko	9:48	S	5:00	Rm 208 Tap 1	S	2.0	18-Jul-17		
				F	5:53	Rm 208 Tap 1	F	<0.001	18-Jul-17		
	27-Jun-17	L. Hisko	9:50	S	5:02	Rm 210 Tap 1	S	5.0	15-Sep-17		
				F	5:55	Rm 210 Tap 1	F	1.0	15-Sep-17		
	27-Jun-17	L. Hisko	9:49	S	5:01	Rm 209 Tap 1	S	2.0	18-Jul-17		
				F	5:54	Rm 209 Tap 1	F	<0.001	18-Jul-17		
	27-Jun-17	L. Hisko	9:51	S	5:03	Rm 115 Tap 1	S	2.0	18-Jul-17		
				F	5:56	Rm 115 Tap 1	F	<0.001	18-Jul-17		
Central	28-Jun-17		28-Jun-17								
Day 2	29-Jun-17	L. Hisko	9:50	S	5:20	Rm 205 Fountain	S	2.0	18-Jul-17		
				F	6:15	Rm 205 Fountain	F	1.0	18-Jul-17		
	29-Jun-17	L. Hisko	9:52	S	5:22	Rm 206 Fountain	S	2.0	18-Jul-17		
				F	6:17	Rm 206 Fountain	F	1.0	18-Jul-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
	29-Jun-17	L. Hisko	9:54	S	5:24	Rm 208 Fountain	S	3.0	18-Jul-17		
				F	6:19	Rm 208 Fountain	F	2.0	18-Jul-17		
	29-Jun-17	L. Hisko	9:56	S	5:26	Rm 209 Fountain	S	3.0	18-Jul-17		
				F	6:21	Rm 209 Fountain	F	2.0	18-Jul-17		
	29-Jun-17	L. Hisko	9:58	S	5:28	Rm 115 Fountain	S	3.0	18-Jul-17		
				F	6:23	Rm 115 Fountain	F	2.0	18-Jul-17		
Central	29-Jun-17		6:33-7:35								
Day 3	30-Jun-17	L. Hisko	9:47	S	5:22	Fountain Hall 207	S	<0.001	18-Jul-17		
				F	6:15	Fountain Hall 207	F	<0.001	18-Jul-17		
	30-Jun-17	L. Hisko	9:49	S	5:24	Rm 208 Trough Tap	S	<0.001	18-Jul-17		
				F	6:16	Rm 208 Trough Tap	F	<0.001	18-Jul-17		
	30-Jun-17	L. Hisko	9:51	S	5:26	Fountain Hall 120	S	<0.001	18-Jul-17		
				F	6:17	Fountain Hall 120	F	<0.001	18-Jul-17		
	30-Jun-17	L. Hisko	9:53	S	5:28	Rm 127 Kindergarten Fountain	S	2.0	18-Jul-17		
				F	6:18	Rm 127 Kindergarten Fountain	F	2.0	18-Jul-17		
Central - Sampling Complete											
Champlain Discovery	25-Sep-17	Flush	25-Sep-17								
Day 1	26-Sep-17	B. Schreader	7:25	S	5:45	Room 104 tap	S	6.0	3-Oct-17		
				F	6:39	Room 104 tap	F	4.0	3-Oct-17		
	26-Sep-17	B. Schreader	7:27	S	5:47	Rm 152 tap	S	15.0	3-Oct-17	Daily flush of tap	Daily flush of tap
				F	6:41	Rm 152 tap	F	5.0	3-Oct-17		
	26-Sep-17	B. Schreader	7:29	S	5:49	Rm 153 tap	S	14.0	3-Oct-17	Daily flush of tap	Daily flush of tap
				F	6:43	Rm 153 tap	F	6.0	3-Oct-17		
	26-Sep-17	B. Schreader	7:31	S	5:51	Rm 105 tap	S	5.0	3-Oct-17		
				F	6:45	Rm 105 tap	F	3.0	3-Oct-17		
	26-Sep-17	B. Schreader	7:33	S	5:53	Rm 107-A tap	S	6.0	3-Oct-17		
				F	6:47	Rm 107-A tap	F	3.0	3-Oct-17		
Champlain Discovery	26-Sep-17		26-Sep-17								
Day 2	27-Sep-17	B. Schreader	7:25	S	5:45	Fountain Outside 152	S	<0.001	3-Oct-17		
				F	6:39	Fountain Outside 152	F	<0.001	3-Oct-17		
	27-Sep-17	B. Schreader	7:27	S	5:47	Fountain Outside 154	S	<0.001	3-Oct-17		
				F	6:41	Fountain Outside 154	F	<0.001	3-Oct-17		
	27-Sep-17	B. Schreader	7:29	S	5:49	Rm 106 Tap	S	5.0	3-Oct-17		
				F	6:43	Rm 106 Tap	F	4.0	3-Oct-17		
	27-Sep-17	B. Schreader	7:31	S	5:51	Rm 108 Tap	S	14.0	3-Oct-17	Daily flush of tap	Daily flush of tap
				F	6:45	Rm 108 Tap	F	5.0	3-Oct-17		
	27-Sep-17	B. Schreader	7:33	S	5:53	Rm 157 Tap	S	21.0	3-Oct-17	Shut tap off - Out of Service	Fixture Changed
				F	6:47	Rm 157 Tap	F	18.0	3-Oct-17		Resample Oct 19/17 Resolved
Champlain Discovery	27-Sep-17	Flush	27-Sep-17								
Day 3	28-Sep-17	B. Schreader	7:25	S	5:45	Rm 154 Tap	S	8.0	13-Oct-17		
				F	6:39	Rm 154 Tap	F	3.0	13-Oct-17		
	28-Sep-17	B. Schreader	7:27	S	5:47	Rm 158 Tap	S	11.0	12-Oct-17	Daily flush of tap	Daily flush of tap
				F	6:41	Rm 158 Tap	F	5.0	12-Oct-17		
	28-Sep-17	B. Schreader	7:29	S	5:49	Rm 115 Tap	S	35.0	12-Oct-17	Daily flush of tap	Daily flush of tap
				F	6:43	Rm 115 Tap	F	4.0	12-Oct-17		
	28-Sep-17	B. Schreader	7:31	S	5:51	Fountain Outside Library	S	<0.001	13-Oct-17		
				F	6:45	Fountain Outside Library	F	<0.001	13-Oct-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
	28-Sep-17	B. Schreader	7:33	S	5:53	Rm 118 Tap	S	3.0	13-Oct-17		
				F	6:47	Rm 118 Tap	F	1.0	13-Oct-17		
Champlain Discovery	28-Sep-17	Flush	28-Sep-17								
Day 4	29-Sep-17	B. Schreader	7:25	S	5:45	Rm 159-B Tap	S	38.0	12-Oct-17	Shut tap off - Out of Service	Tap capped off - Out of Service
				F	6:39	Rm 159-B Tap	F	19.0	12-Oct-17		
	29-Sep-17	B. Schreader	7:27	S	5:47	Rm 119 Tap	S	2.0	13-Oct-17		
				F	6:41	Rm 119 Tap	F	1.0	13-Oct-17		
	29-Sep-17	B. Schreader	7:29	S	5:49	Rm 160 Tap	S	10.0	13-Oct-17		
				F	6:43	Rm 160 Tap	F	5.0	13-Oct-17		
	29-Sep-17	B. Schreader	7:31	S	5:51	Rm 122 Tap	S	86.0	12-Oct-17	Daily flush of tap	Daily flush of tap
				F	6:45	Rm 122 Tap	F	3.0	12-Oct-17		
Champlain Discovery	02-Oct-17	Flush	2-Oct-17								
Day 5	03-Oct-17	B. Schreader	7:25	S	5:45	Room 120 Tap	S	3.0	13-Oct-17		
				F	6:39	Room 120 Tap	F	2.0	13-Oct-17		
	03-Oct-17	B. Schreader	7:27	S	5:47	Rm 161 Tap	S	6.0	13-Oct-17		
				F	6:41	Rm 161 Tap	F	2.0	13-Oct-17		
	03-Oct-17	B. Schreader	7:29	S	5:49	Rm 164 Tap	S	2.0	13-Oct-17		
				F	6:43	Rm 164 Tap	F	<0.001	13-Oct-17		
	03-Oct-17	B. Schreader	7:31	S	5:51	Rm 123 Fountain	S	<0.001	13-Oct-17		
				F	6:45	Rm 123 Fountain	F	<0.001	13-Oct-17		
Champlain Discovery	03-Oct-17	Flush	03-Oct-17								
Day 6	04-Oct-17	B. Schreader	7:25	S	5:45	Rm 161 Fountain	S	3.0	13-Oct-17		
				F	6:42	Rm 161 Fountain	F	1.0	13-Oct-17		
	04-Oct-17	B. Schreader	7:28	S	5:48	Fountain Hall 123	S	1.0	13-Oct-17		
				F	6:45	Fountain Hall 123	F	<0.001	13-Oct-17		
	04-Oct-17	B. Schreader	7:31	S	5:51	Rm 123 Tap	S	<0.001	13-Oct-17		
				F	6:48	Rm 123 Tap	F	<0.001	13-Oct-17		
	04-Oct-17	B. Schreader	7:34	S	5:54	Room 127 Fountain	S	<0.001	13-Oct-17		
				F	6:51	Room 127 Fountain	F	<0.001	13-Oct-17		
Champlain Discovery	04-Oct-17	Flush	04-Oct-17								
Day 7	05-Oct-17	B. Schreader	7:25	S	5:45	Rm 164 Fountain	S	<0.001	25-Oct-17		
				F	6:39	Rm 164 Fountain	F	<0.001	25-Oct-17		
	05-Oct-17	B. Schreader	7:27	S	5:47	Rm 127 Tap	S	<0.001	25-Oct-17		
				F	6:41	Rm 127 Tap	F	<0.001	25-Oct-17		
	05-Oct-17	B. Schreader	7:29	S	5:49	Rm 165 Staff Rm	S	7.0	25-Oct-17		
				F	6:43	Rm 165 Staff Rm	F	<0.001	25-Oct-17		
	05-Oct-17	B. Schreader	7:31	S	5:51	Rm 133 Tap 1	S	8.0	25-Oct-17		
				F	6:45	Rm 133 Tap 1	F	2.0	25-Oct-17		
Champlain Discovery	11-Oct-17	Flush	11-Oct-17								
Day 8	12-Oct-17	B. Schreader	7:25	S	5:45	Room 133 Sink #2	S	12.0	24-Oct-17	Flush Daily	Flush Daily
				F	6:40	Room 133 Sink #2	F	1.0	24-Oct-17		
	12-Oct-17	B. Schreader	7:27	S	5:47	Rm 130 Fountain	S	9.0	25-Oct-17		
				F	6:42	Rm 130 Fountain	F	3.0	25-Oct-17		
	12-Oct-17	B. Schreader	7:31	S	5:51	Rm B-18 Fountain	S	<0.001	25-Oct-17		
				F	6:46	Rm B-18 Fountain	F	<0.001	25-Oct-17		
Champlain Discovery	12-Oct-17	Flush	12-Oct-17								
Day 9	13-Oct-17	B. Schreader	7:25	S	5:45	Fountain at B53	S	<0.001	25-Oct-17		
				F	6:39	Fountain at B53	F	<0.001	25-Oct-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
	13-Oct-17	B. Schreader	7:27	S	5:47	Rm B16 Tap	S	<0.001	25-Oct-17		
				F	6:42	Rm B16 Tap	F	<0.001	25-Oct-17		
	13-Oct-17	B. Schreader	7:29	S	5:49	Rm B17 Tap	S	<0.001	25-Oct-17		
				F	6:43	Rm B17 Tap	F	<0.001	25-Oct-17		
	13-Oct-17	B. Schreader	7:31	S	5:51	Fountain at B60	S	<0.001	25-Oct-17		
				F	6:45	Fountain at B60	F	<0.001	25-Oct-17		
Champlain Discovery	16-Oct-17	Flush	16-Oct-17								
Day 10	17-Oct-17	B. Schreader	7:25	S	5:45	Room B15 Tap	S	3.0	25-Oct-17		
				F	6:39	Room B15 Tap	F	2.0	25-Oct-17		
	17-Oct-17	B. Schreader	7:27	S	5:47	Rm B18 Tap	S	<0.001	25-Oct-17		
				F	6:41	Rm B18 Tap	F	<0.001	25-Oct-17		
	17-Oct-17	B. Schreader	7:29	S	5:49	Rm B19 Tap	S	<0.001	25-Oct-17		
				F	6:43	Rm B19 Tap	F	<0.001	25-Oct-17		
	17-Oct-17	B. Schreader	7:31	S	5:51	Rm B60 Tap	S	<0.001	25-Oct-17		
				F	6:45	Rm B60 Tap	F	<0.001	25-Oct-17		
Champlain Discovery	18-Oct-17		18-Oct-17								
Day 11	19-Oct-17	B. Schreader	7:40	S	6:00	Rm 157 Tap Resample	S	9.0	6-Nov-17	RESOLVED	Resolved - NFA
				F	6:46	Rm 157 Tap Resample	F	3.0	6-Nov-17		
Champlain - Sampling Complete											
Cobden	01-Jun-17	Flush	01-Jun-17								
Day 1	02-Jun-17	Irene Mousseau	6:00	S	5:00	Teachers Annex	S	4.0	27-Jun-17		
				F	5:54	Teachers Annex	F	2.0	27-Jun-17		
	02-Jun-17	Irene Mousseau	6:01	S	5:01	Rm 4 - Tap 1 Trough	S	<0.001	27-Jun-17		
				F	5:54	Rm 4 - Tap 1 Trough	F	<0.001	27-Jun-17		
	02-Jun-17	Irene Mousseau	6:02	S	5:02	Rm 1 - Tap 1 Trough	S	1.0	27-Jun-17		
				F	5:55	Rm 1 - Tap 1 Trough	F	<0.001	27-Jun-17		
	02-Jun-17	Irene Mousseau	6:03	S	5:04	Rm 2 Annex	S	1.0	27-Jun-17		
				F	5:57	Rm 2 Annex	F	<0.001	27-Jun-17		
	02-Jun-17	Irene Mousseau	6:04	S	5:05	Rm 3 Annex	S	<0.001	27-Jun-17		
				F	5:58	Rm 3 Annex	F	<0.001	27-Jun-17		
Cobden	06-Jun-17	Flush	06-Jun-17								
Day 2	07-Jun-17	Irene Mousseau	6:18	S	5:18	Classroom #4 - Tap 2 small sink	S	<0.001	27-Jun-17		
				F	6:10	Classroom #4 - Tap 2 small sink	F	<0.001	27-Jun-17		
	07-Jun-17	Irene Mousseau	6:19	S	5:20	Classroom #3 - fountain #1	S	1.0	27-Jun-17		
				F	6:12	Classroom #3 - fountain #1	F	<0.001	27-Jun-17		
	07-Jun-17	Irene Mousseau	6:20	S	5:22	Classroom #2 - fountain	S	1.0	27-Jun-17		
				F	6:14	Classroom #2 - fountain	F	<0.001	27-Jun-17		
	07-Jun-17	Irene Mousseau	6:22	S	5:24	Annex Hall Fountain #2	S	2.0	27-Jun-17		
				F	6:15	Annex Hall Fountain #2	F	1.0	27-Jun-17		
	07-Jun-17	Irene Mousseau	6:16	S	5:16	Classroom 1 - Tap 2 small sink	S	<0.001	27-Jun-17		
				F	6:09	Classroom 1 - Tap 2 small sink	F	<0.001	27-Jun-17		
Cobden	07-Jun-17	Flush	10-11:09								
Day 3	08-Jun-17	Irene Mousseau	6:25	S	5:25	Rm 1 Fountain #2	S	<0.001	27-Jun-17		
				F	6:24	Rm 1 Fountain #2	F	<0.001	27-Jun-17		
	08-Jun-17	Irene Mousseau	6:27	S	5:32	Rm 24 Tap 1 - Music	S	1.0	27-Jun-17		
				F	6:26	Rm 24 Tap 1 - Music	F	<0.001	27-Jun-17		
	08-Jun-17	Irene Mousseau	6:25	S	5:33	Rm 10 - Tap 1, 1st floor	S	2.0	27-Jun-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
				F	6:23	Rm 10 - Tap 1, 1st floor	F	1.0	27-Jun-17		
	08-Jun-17	Irene Mousseau	6:28	S	5:33	Rm 21 - Tap 1	S	4.0	27-Jun-17		
				F	6:24	Rm 21 - Tap 1	F	1.0	27-Jun-17		
	08-Jun-17	Irene Mousseau	6:25	S	5:34	Rm 23 - Tap 1 Custodial	S	3.0	27-Jun-17		
				F	6:20	Rm 23 - Tap 1 Custodial	F	1.0	27-Jun-17		
Cobden	08-Jun-17	Flush	08-Jun-17								
Day 4	09-Jun-17	Irene Mousseau	6:28	S	5:28	Staff Rm - Tap 1 front door	S	4.0	27-Jun-17		
				F	6:26	Staff Rm - Tap 1 front door	F	1.0	27-Jun-17		
	09-Jun-17	Irene Mousseau	6:31	S	5:32	Rm 7	S	9.0	27-Jun-17		
				F	6:23	Rm 7	F	4.0	27-Jun-17		
	09-Jun-17	Irene Mousseau	6:31	S	5:32	Rm 9	S	42.0	23-Jun-17	Shut off, investigate	Tap fixtures changed Jun 27
				F	6:25	Rm 9	F	93.0	23-Jun-17		Resample Jun 29/2017 - Removed
	09-Jun-17	Irene Mousseau	6:32	S	5:34	Rm 6	S	86.0	23-Jun-17	Shut off, investigate	Tap fixtures changed Jun 27
				F	6:20	Rm 6	F	46.0	23-Jun-17		Resample Jun 29/2017 - Resolved
	09-Jun-17	Irene Mousseau	6:32	S	5:35	Rm 109 - Tap 1, staff kitchen	S	4.0	27-Jun-17		
				F	6:21	Rm 109 - Tap 1, staff kitchen	F	1.0	27-Jun-17		
Cobden	12-Jun-17	Flush	12-Jun-17								
Day 5	13-Jun-17	Irene Mousseau	6:30	S	5:30	Rm 33 - Tap 1	S	5.0	27-Jun-17		
				F	6:26	Rm 33 - Tap 1	F	2.0	27-Jun-17		
	13-Jun-17	Irene Mousseau	6:30	S	5:30	Staff Rm - Tap 2 by window	S	35.0	23-Jun-17	Shut off, investigate	Tap fixtures changed Jun 27
				F	6:28	Staff Rm - Tap 2 by window	F	18.0	23-Jun-17		Resampled Jun 29/2017 - Removed
	13-Jun-17	Irene Mousseau	6:30	S	5:31	Rm 30 - Tap 1	S	12.0	23-Jun-17	Flush Daily	Daily flush of tap
				F	6:26	Rm 30 - Tap 1	F	5.0	23-Jun-17		
	13-Jun-17	Irene Mousseau	6:30	S	5:34	Fountain by Rm 203	S	15.0	23-Jun-17	Flush Daily	Daily flush of tap
				F	6:25	Fountain by Rm 203	F	4.0	23-Jun-17		
	13-Jun-17	Irene Mousseau	6:33	S	5:35	Rm 45 - Tap 1, Island	S	5.0	27-Jun-17		
				F	6:20	Rm 45 - Tap 1, Island	F	2.0	27-Jun-17		
Cobden	19-Jun-17	Flush	10-11:00								
Day 6	20-Jun-17	Irene Mousseau	6:37	S	5:37	Room 40	S	9.0	10-Jul-17		
				F	6:26	Room 40	F	3.0	10-Jul-17		
	20-Jun-17	Irene Mousseau	6:37	S	5:37	Rm 41	S	14.0	9-Jul-17	Flush Daily	Daily flush of tap
				F	6:24	Rm 41	F	4.0	9-Jul-17		
	20-Jun-17	Irene Mousseau	6:38	S	5:38	Rm 42	S	5.0	10-Jul-17		
				F	6:29	Rm 42	F	2.0	10-Jul-17		
	20-Jun-17	Irene Mousseau	6:38	S	5:38	Rm 43	S	6.0	10-Jul-17		
				F	6:29	Rm 43	F	2.0	10-Jul-17		
	20-Jun-17	Irene Mousseau	6:40	S	5:40	Rm 45 Sink #2 Middle Island	S	4.0	10-Jul-17		
				F	6:29	Rm 45 Sink #2	F	2.0	10-Jul-17		
Cobden	20-Jun-17	Flush	10:02-11:05								
Day 7	21-Jun-17	Irene Mousseau	6:27	S	5:32	1st Flr WFS Fountain #1	S	<0.001	10-Jul-17		
				F	6:32	1st Flr WFS Fountain #1	F	<0.001	10-Jul-17		
	21-Jun-17	Irene Mousseau	6:30	S	5:35	Rm 44	S	4.0	10-Jul-17		
				F	6:25	Rm 44	F	2.0	10-Jul-17		
	21-Jun-17	Irene Mousseau	6:31	S	5:36	RM 46	S	7.0	10-Jul-17		
				F	6:24	Rm 46	F	3.0	10-Jul-17		
	21-Jun-17	Irene Mousseau	6:34	S	5:39	Rm 45 Sink 3	S	6.0	10-Jul-17		
				F	6:24	Rm 45 Sink 3	F	2.0	10-Jul-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
	21-Jun-17	Irene Mousseau	6:40	S	5:45	Staff Rm Sink 3 by Washer	S	8.0	10-Jul-17		
				F	6:31	Staff Rm Sink 3 by Washer	F	3.0	10-Jul-17		
Cobden	28-Jun-17	Flush	10:16-11:16								
Day 8	29-Jun-17	Irene Mousseau	6:19	S	5:35	Rm 47 - Counsellors Rm	S	14.0	14-Jul-17	Daily Flush	Daily flush of tap
				F	6:36	Rm 47 - Counsellors Rm	F	6.0	14-Jul-17		
Resample #1	29-Jun-17	Irene Mousseau	6:22	S	5:38	Staff Rm - Tap 2 by window	S	88.0	17-Jul-17	Take out of service & investigation	Taps and sink removed
				F	6:41	Staff Rm - Tap 2 by window	F	11.0	17-Jul-17		NFA
	29-Jun-17	Irene Mousseau	6:24	S	5:41	Library Work Area	S	16.0	14-Jul-17	Daily Flush	Daily flush of tap
				F	6:34	Library Work Area	F	5.0	14-Jul-17		
	29-Jun-17	Irene Mousseau	6:27	S	5:44	Annex Newer fountain	S	<0.001	14-Jul-17		
				F	6:30	Annex Newer fountain	F	<0.001	14-Jul-17		
Resample #1	29-Jun-17	Irene Mousseau	6:23	S	5:40	Room 6	S	7.0	14-Jul-17	Resample results within acceptable perimeters	Resolved
				F	6:32	Room 6	F	3.0	14-Jul-17		
Resample #1	29-Jun-17	Irene Mousseau	6:24	S	5:41	Room 9	S	195.0	14-Jul-17	Take out of service & investigate	Sink and taps removed Sep14
				F	6:33	Room 9	F	15.0	14-Jul-17		NFA
	29-Jun-17	Irene Mousseau	6:20	S	5:36	2nd Floor Newer Fountain	S	<0.001	14-Jul-17		
				F	6:38	2nd Floor Newer Fountain	F	<0.001	14-Jul-17		
Cobden - Sampling Complete											
Eganville	16-Oct-17	Flush	10-11:00								
Day 1	17-Oct-17	C. Kumm	6:02	S	5:02	Activity Rm Tap	S	2.0	6-Nov-17		
				F	5:57	Activity Rm Tap	F	<0.001	6-Nov-17		
	17-Oct-17	C. Kumm	6:04	S	5:04	Rm 11 Fountain	S	2.0	6-Nov-17		
				F	5:58	Rm 11 Fountain	F	<0.001	6-Nov-17		
	17-Oct-17	C. Kumm	6:06	S	5:06	Rm 10 Tap	S	4.0	6-Nov-17		
				F	5:59	Rm 10 Tap	F	1.0	6-Nov-17		
Eganville	17-Oct-17	Flush	10-11:00								
Day 3	18-Oct-17	C. Kumm	7:02	S	6:02	Rm 11 Tap	S	88.0	2-Nov-17	Take out of service & investigate	Change taps
				F	6:57	Rm 11 Tap	F	16.0	2-Nov-17		Taps Changed Nov 16 - Resample
	18-Oct-17	C. Kumm	7:04	S	6:04	Rm 10 Fountain	S	2.0	6-Nov-17		
				F	6:58	Rm 10 Fountain	F	2.0	6-Nov-17		
	18-Oct-17	C. Kumm	7:06	S	6:06	Basement Hall Fountain (old style)	S	<0.001	6-Nov-17		
				F	6:59	Basement Hall Fountain (old style)	F	<0.001	6-Nov-17		
Eganville	18-Oct-17	Flush	10-11:00								
	19-Oct-17	C. Kumm	7:02	S	6:02	Rm 9 Fountain	S	7.0	6-Nov-17		
				F	6:57	Rm 9 Fountain	F	3.0	6-Nov-17		
Eganville	08-Jun-17	Flush	10-11:00								
Day 1	09-Jun-17	C. Kumm	6:12	S	5:12	Rm 20 Fountain	S	2.0	5-Jul-17		
				F	6:02	Rm 20 Fountain	F	<0.001	5-Jul-17		
Eganville	19-Oct-17	Flush	10-11:00								
Day 2	20-Oct-17	C. Kumm	7:02	S	6:02	Rm 21 Fountain	S	2.0	6-Nov-17		
				F	6:57	Rm 21 Fountain	F	<0.001	6-Nov-17		
	20-Oct-17	C. Kumm	7:04	S	6:04	Rm 22 Fountain	S	3.0	6-Nov-17		
				F	6:58	Rm 22 Fountain	F	2.0	6-Nov-17		
	20-Oct-17	C. Kumm	7:06	S	6:06	Rm 23 Fountain	S	4.0	6-Nov-17		
				F	6:59	Rm 23 Fountain	F	2.0	6-Nov-17		
	20-Oct-17	C. Kumm	7:08	S	6:08	2nd Flr Hall Fountain	S	<0.001	6-Nov-17		
				F	7:00	2nd Flr Hall Fountain	F	<0.001	6-Nov-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
	20-Jun-17	M. Tate	6:30	S	6:30	Main Office	S	8.0	10-Jul-17	Out of Service & Investigate	Tap changed
				F	7:20	Main Office	F	25.0	10-Jul-17		Resampled Sep 29/2017 - Resolved
	20-Jun-17	M. Tate	6:31	S	6:31	Rm 139 (Angelas Rm)	S	4.0	10-Jul-17		
				F	7:21	Rm 139	F	2.0	10-Jul-17		
	20-Jun-17	M. Tate	6:32	S	6:32	Rm 109A Custodial Office	S	24.0	10-Jul-17	Daily Flush	Daily flush of tap
				F	7:22	Rm 109A Custodial Office	F	8.0	10-Jul-17		
	20-Jun-17	M. Tate	6:33	S	6:33	Rm 5	S	10.0	10-Jul-17		
				F	7:23	Rm 5	F	4.0	10-Jul-17		
	20-Jun-17	M. Tate	6:34	S	6:34	Rm 3	S	23.0	10-Jul-17	Daily Flush	Daily flush of tap
				F	7:24	Rm 3	F	9.0	10-Jul-17		
	20-Jun-17	M. Tate	6:35	S	6:35	Rm 1 - Tap 1	S	1.0	10-Jul-17		
				F	7:25	Rm 1 - Tap 1	F	<0.001	10-Jul-17		
Day 4 - Herman St.	25-Sep-17	Flush	25-Sep-17								
	26-Sep-17	M. Tate	6:30	S	6:30	Room 6 Tap	S	165.0	6-Oct-17	Out of Service & Investigate	Work Order in to Change Tap
				F	7:19	Room 6 Tap	F	37.0	6-Oct-17		
	26-Sep-17	M. Tate	6:31	S	6:31	Room 4 Tap	S	11.0	6-Oct-17	Daily Flush Tap	Daily Flush Tap
				F	7:20	Room 4 Tap	F	7.0	6-Oct-17		
	26-Sep-17	M. Tate	6:32	S	6:32	Staffroom Tap #2	S	24.0	6-Oct-17	Flushed results on border - Resample Out of Service until results back	Resampled Oct 12/2017 (Tap removed Nov 16/17)
				F	7:21	Staffroom Tap #2	F	10.0	6-Oct-17		
	26-Sep-17	M. Tate	6:33	S	6:33	Room 2 Tap	S	4.0	11-Oct-17		
				F	7:22	Room 2 Tap	F	2.0	11-Oct-17		
	26-Sep-17	M. Tate	6:34	S	6:34	Room 1 Tap #2	S	3.0	11-Oct-17		
				F	7:23	Room 1 Tap #2	F	2.0	11-Oct-17		
Day 5 - Herman St.	27-Sep-17	Flush	27-Sep-17								
	28-Sep-17	M. Tate	6:30	S	6:30	Room 6 Fountain	S	54.0	6-Oct-17	Out of Service & Investigate	Fountain removed Nov 16/17
				F	7:19	Room 6 Fountain	F	21.0	6-Oct-17		
	28-Sep-17	M. Tate	6:31	S	6:31	Room 4 Fountain	S	10.0	11-Oct-17		
				F	7:20	Room 4 Fountain	F	4.0	11-Oct-17		
	28-Sep-17	M. Tate	6:33	S	6:33	Room 2 Fountain	S	4.0	11-Oct-17		
				F	7:22	Room 2 Fountain	F	2.0	11-Oct-17		
	28-Sep-17	M. Tate	6:34	S	6:34	Room 1 Fountain #1	S	2.0	11-Oct-17		
				F	7:23	Room 1 Fountain #1	F	1.0	11-Oct-17		
	28-Sep-17	M. Tate	6:32	S	6:32	Staffroom Sink Tap # 1	S	71.0	12-Oct-17	Out of Service & Investigate	Filter Installed Nov 16/17 Tap resampled Nov 17/17
				F	7:21	Staffroom Sink Tap # 1	F	26.0	12-Oct-17		
Day 6 - Herman St.	28-Sep-17	Flush	28-Sep-17								
	29-Sep-17	M. Tate	6:30	S	6:30	Main Office Sink - Resample	S	4.0	13-Oct-17	Resolved	Resolved
				F	7:18	Main Office Sink - Resample	F	2.0	13-Oct-17		
	29-Sep-17	M. Tate	6:31	S	6:31	Room 5 Fountain	S	13.0	12-Oct-17	Out of Service & Investigate	Fountain removed Nov 16/17 NFA
				F	7:19	Room 5 Fountain	F	24.0	12-Oct-17		
	29-Sep-17	M. Tate	6:32	S	6:32	Room 3 Fountain	S	32.0	12-Oct-17	Out of Service & Investigate	Fountain removed Nov 16/17 NFA
				F	7:20	Room 3 Fountain	F	14.0	12-Oct-17		
	29-Sep-17	M. Tate	6:33	S	6:33	Room 1 Fountain #2	S	2.0	13-Oct-17		
				F	7:21	Room 1 Fountain #2	F	3.0	13-Oct-17		
Day 7 - Herman St.	02-Oct-17	Flush	02-Oct-17								
	03-Oct-17	M. Tate	6:30	S	6:30	Room 1 - Tap #3	S	2.0	6-Nov-17		
				F	7:16	Room 1 - Tap #3	F	2.0	6-Nov-17		
Day 8 - Herman St.	11-Oct-17	Flush	11-Oct-17								
	12-Oct-17	M. Tate	6:30	S	6:30	Staff Room Tap #2 - Resample	S	15.0	23-Oct-17	Out of Service & Investigate	Tap Removed Nov 16/17

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
				F	7:16	Staff Room Tap #2 - Resample	F	76.0	23-Oct-17		NFA
Herman St. - Sampling Complete											
Highview Day 1											
	25-Sep-17	Flush	25-Sep-17								
	26-Sep-17	S. Liedtke	6:20	S	5:05	Rm 103 Tap #1	S	1.0	13-Oct-17		
				F	6:01	Rm 103 Tap #1	F	<0.001	13-Oct-17		
	26-Sep-17	S. Liedtke	6:23	S	5:08	Rm 105 Tap #1	S	<0.001	13-Oct-17		
				F	6:03	Rm 105 Tap #1	F	<0.001	13-Oct-17		
	26-Sep-17	S. Liedtke	6:25	S	5:10	Rm 106 Tap #1	S	<0.001	13-Oct-17		
				F	6:05	Rm 106 Tap #1	F	<0.001	13-Oct-17		
	26-Sep-17	S. Liedtke	6:27	S	5:12	Rm 114 Tap 1	S	1.0	13-Oct-17		
				F	6:06	Rm 114 Tap 1	F	<0.001	13-Oct-17		
Highview Day 2											
	26-Sep-17	Flush	26-Sep-17								
	27-Sep-17	S. Liedtke	6:20	S	5:05	Rm 104 Tap 1	S	<0.001	13-Oct-17		
				F	6:01	Rm 104 Tap 1	F	<0.001	13-Oct-17		
	27-Sep-17	S. Liedtke	6:22	S	5:07	Rm 106 Tap 2	S	6.0	13-Oct-17		
				F	6:03	Rm 106 Tap 2	F	2.0	13-Oct-17		
	27-Sep-17	S. Liedtke	6:24	S	5:09	Rm 114 Tap 2	S	2.0	13-Oct-17		
				F	6:05	Rm 114 Tap 2	F	<0.001	13-Oct-17		
Highview Day 3											
	27-Sep-17	Flush	27-Sep-17								
	28-Sep-17	S. Liedtke	6:15	S	5:00	Rm 106 Fountain	S	2.0	13-Oct-17		
				F	5:56	Rm 106 Fountain	F	3.0	13-Oct-17		
	28-Sep-17	S. Liedtke	6:17	S	5:02	WFS Fountain 1 Corridor 203	S	<0.001	13-Oct-17		
				F	5:57	WFS Fountain 1 Corridor 203	F	<0.001	13-Oct-17		
Highview Day 4											
	28-Sep-17	Flush	28-Sep-17								
	29-Sep-17	S. Liedtke	6:15	S	5:00	Tap #1 Sec Office/Storage 204	S	11.0	19-Oct-17	Daily Flush Tap	Daily Flush Tap
				F	5:52	Tap #1 Sec Office/Storage 204	F	4.0	19-Oct-17		
	29-Sep-17	S. Liedtke	6:17	S	5:02	Tap #1 Rm 205	S	9.0	24-Oct-17		
				F	5:53	Tap #1 Rm 205	F	4.0	24-Oct-17		
	29-Sep-17	S. Liedtke	6:19	S	5:04	Tap #1 Rm 206	S	8.0	19-Oct-17		
				F	5:54	Tap #1 Rm 206	F	4.0	19-Oct-17		
	29-Sep-17	S. Liedtke	6:21	S	5:06	Tap #1 Rm 207	S	4.0	24-Oct-17		
				F	5:55	Tap #1 Rm 207	F	2.0	24-Oct-17		
Highview Day 5											
	04-Oct-17	Flush	04-Oct-17								
	05-Oct-17	S. Liedtke	6:15	S	5:00	Tap #2 Rm 207	S	1.0	24-Oct-17		
				F	5:50	Tap #2 Rm 207	F	<0.001	24-Oct-17		
	05-Oct-17	S. Liedtke	6:17	S	5:02	Tap #1 Kitchen Rm 216	S	11.0	23-Oct-17	Daily Flush	Daily Flush Tap
				F	5:51	Tap #1 Kitchen Rm 216	F	5.0	23-Oct-17		
	05-Oct-17	S. Liedtke	6:19	S	5:04	Tap #1 Rm 308	S	2.0	24-Oct-17		
				F	5:52	Tap #1 Rm 308	F	<0.001	24-Oct-17		
Highview Day 6											
	05-Oct-17	Flush	05-Oct-17								
	06-Oct-17	S. Liedtke	6:19	S	5:04	Tap #1 Rm 303	S	<0.001	24-Oct-17		
				F	5:54	Tap #1 Rm 303	F	<0.001	24-Oct-17		
	06-Oct-17	S. Liedtke	6:21	S	5:06	Tap #1 Rm 304	S	<0.001	24-Oct-17		
				F	5:55	Tap #1 Rm 304	F	<0.001	24-Oct-17		
	06-Oct-17	S. Liedtke	6:15	S	5:00	Tap 1 Rm 310	S	1.0	24-Oct-17		
				F	5:52	Tap 1 Rm 310	F	<0.001	24-Oct-17		
	06-Oct-17	S. Liedtke	6:17	S	5:02	Tap 1 Rm 311	S	<0.001	24-Oct-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
				F	5:53	Tap 1 Rm 311	F	<0.001	24-Oct-17		
Highview	10-Oct-17	Flush	10-Oct-17								
Day 7	11-Oct-17	S. Liedtke	6:15	S	5:00	Tap 2 Rm 311	S	<0.001	24-Oct-17		
				F	5:52	Tap 2 Rm 311	F	<0.001	24-Oct-17		
	11-Oct-17	S. Liedtke	6:17	S	5:02	Fountain Corridor 302	S	<0.001	24-Oct-17		
				F	5:53	Fountain Corridor 302	F	<0.001	24-Oct-17		
	11-Oct-17	S. Liedtke	6:19	S	5:04	Tap #1 Rm 305	S	<0.001	24-Oct-17		
				F	5:54	Tap #1 Rm 305	F	<0.001	24-Oct-17		
	11-Oct-17	S. Liedtke	6:21	S	5:06	Fountain #2 Corridor 203	S	<0.001	24-Oct-17		
				F	5:55	Fountain #2 Corridor 203	F	<0.001	24-Oct-17		
Highview	11-Oct-17	Flush	11-Oct-17								
Day 8	12-Oct-17	S. Liedtke	6:15	S	5:00	Tap #1 Rm 405	S	2.0	24-Oct-17		
				F	5:52	Tap #1 Rm 405	F	<0.001	24-Oct-17		
	12-Oct-17	S. Liedtke	6:17	S	5:02	Tap #1 Rm 406	S	1.0	24-Oct-17		
				F	5:53	Tap #1 Rm 406	F	<0.001	24-Oct-17		
	12-Oct-17	S. Liedtke	6:19	S	5:04	Tap #1 Rm 407	S	3.0	24-Oct-17		
				F	5:54	Tap #1 Rm 407	F	1.0	24-Oct-17		
	12-Oct-17	S. Liedtke	6:21	S	5:06	Rm 408 Tap 1	S	1.0	25-Oct-17		
				F	5:55	Rm 408 Tap 1	F	<0.001	25-Oct-17		
Highview	12-Oct-17	Flush	12-Oct-17								
Day 9	13-Oct-17	S. Liedtke	6:15	S	5:00	Fountain Corridor 401	S	<0.001	25-Oct-17		
				F	5:52	Fountain Corridor 401	F	<0.001	25-Oct-17		
	13-Oct-17	S. Liedtke	6:17	S	5:02	Staff Room #414 Tap 1	S	1.0	25-Oct-17		
				F	5:53	Staff Room #414 Tap 1	F	<0.001	25-Oct-17		
	13-Oct-17	S. Liedtke	6:19	S	5:04	Rm 511 Tap 1	S	<0.001	25-Oct-17		
				F	5:54	Rm 511 Tap 1	F	<0.001	25-Oct-17		
	13-Oct-17	S. Liedtke	6:21	S	5:06	Rm 503 Tap 1	S	<0.001	25-Oct-17		
				F	5:55	Rm 503 Tap 1	F	<0.001	25-Oct-17		
Highview	16-Oct-17	Flush	16-Oct-17								
Day 10	17-Oct-17	S. Liedtke	6:15	S	5:00	Rm 510 Tap 1	S	1.0	25-Oct-17		
				F	5:50	Rm 510 Tap 1	F	<0.001	25-Oct-17		
	17-Oct-17	S. Liedtke	6:17	S	5:02	Rm 504 Tap 1	S	<0.001	25-Oct-17		
				F	5:51	Rm 504 Tap 1	F	<0.001	25-Oct-17		
	17-Oct-17	S. Liedtke	6:19	S	5:04	Rm 505 Tap 1	S	1.0	25-Oct-17		
				F	5:52	Rm 505 Tap 1	F	<0.001	25-Oct-17		
Highview	17-Oct-17	Flush	17-Oct-17								
Day 11	18-Oct-17	S. Liedtke	6:17	S	5:02	Fountain/Corridor 502	S	<0.001	25-Oct-17		
				F	5:51	Fountain/Corridor 502	F	<0.001	25-Oct-17		
	18-Oct-17	S. Liedtke	6:19	S	5:04	Room 508 Tap 1	S	<0.001	25-Oct-17		
				F	5:52	Room 508 Tap 1	F	<0.001	25-Oct-17		
	18-Oct-17	S. Liedtke	6:15	S	5:00	Rm 511 Tap 2	S	1.0	25-Oct-17		
				F	5:50	Rm 511 Tap 2	F	<0.001	25-Oct-17		
Highview - Sampling Complete											
Killaloe	06-Jun-17	Flush	06-Jun-17								
Day 1	07-Jun-17	P. Trebinskie	11:35	S	5:05	Fountain #1	S	2.0	5-Jul-17		
				F	6:04	Fountain #1	F	2.0	5-Jul-17		
	07-Jun-17	P. Trebinskie	11:38	S	5:08	Rm 108	S	<0.001	5-Jul-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
				F	6:05	Rm 108	F	<0.001	5-Jul-17		
	07-Jun-17	P. Trebinskie	11:40	S	5:10	Rm 106	S	<0.001	5-Jul-17		
				F	6:07	Rm 106	F	<0.001	5-Jul-17		
	07-Jun-17	P. Trebinskie	11:43	S	5:13	Fountain #2	S	3.0	5-Jul-17		
				F	6:09	Fountain #2	F	2.0	5-Jul-17		
	07-Jun-17	P. Trebinskie	11:45	S	5:15	Fountain # 3	S	7.0	5-Jul-17		
				F	6:10	Fountain # 3	F	4.0	5-Jul-17		
	07-Jun-17	P. Trebinskie	11:47	S	5:17	Rm 136	S	2.0	5-Jul-17		
				F	6:12	Rm 136	F	2.0	5-Jul-17		
Killaloe	12-Jun-17	Flush	12-Jun-17								
Day 2	13-Jun-17	P. Trebinskie	11:44	S	5:14	Rm 120 Tap 1	S	<0.001	5-Jul-17		
				F	6:08	Rm 120 Tap 1	F	<0.001	5-Jul-17		
	13-Jun-17	P. Trebinskie	11:46	S	5:16	Rm 121	S	2.0	5-Jul-17		
				F	6:09	Rm 121	F	1.0	5-Jul-17		
	13-Jun-17	P. Trebinskie	11:47	S	5:17	Rm 122	S	<0.001	5-Jul-17		
				F	6:10	Rm 122	F	<0.001	5-Jul-17		
	13-Jun-17	P. Trebinskie	11:49	S	5:19	Rm 128	S	5.0	5-Jul-17		
				F	6:12	Rm 128	F	2.0	5-Jul-17		
	13-Jun-17	P. Trebinskie	11:50	S	5:20	Rm 134A Tap 1 - Treated	S	43.0	4-Jul-17	Out of Service & Investigate	Tap replaced
				F	6:13	Rm 134A Tap 1 - Treated	F	12.0	4-Jul-17		Resampled Oct 12/2017 - Daily Flush
Killaloe	20-Jun-17	Flush	20-Jun-17								
Day 3	21-Jun-17	P. Trebinskie	11:53	S	5:26	Rm 120 - Tap 2	S	<0.001	10-Jul-17		
				F	6:20	Rm 120 - Tap 2	F	<0.001	10-Jul-17		
	21-Jun-17	P. Trebinskie	11:56	S	5:29	Rm 107	S	<0.001	10-Jul-17		
				F	6:22	Rm 107	F	<0.001	10-Jul-17		
	21-Jun-17	P. Trebinskie	11:57	S	5:30	Rm 123	S	<0.001	10-Jul-17		
				F	6:23	Rm 123	F	<0.001	10-Jul-17		
	21-Jun-17	P. Trebinskie	12:00	S	5:33	Rm 134A Tap 2	S	<0.001	10-Jul-17		
				F	6:25	Rm 134A Tap 2	F	<0.001	10-Jul-17		
Killaloe	26-Jun-17	Flush	26-Jun-17								
Day 4	27-Jun-17	P. Trebinskie	11:36	S	5:06	Rm 120 Tap #3	S	<0.001	14-Jul-17		
				F	5:51	Rm 120 Tap #3	F	<0.001	14-Jul-17		
Killaloe	11-Oct-17	Flush	11-Oct-17								
Day 5	12-Oct-17	P. Trebinskie	12:10	S	5:43	Fountain #4	S	<0.001	23-Oct-17		
				F	6:34	Fountain #4	F	<0.001	23-Oct-17		
	12-Oct-17	P. Trebinskie	12:13	S	5:46	Rm 134A Tap 1 - Treated - RESAMPLE	S	14.0	23-Oct-17	Daily Flush	Daily Flush
				F	6:37	Rm 134A Tap 1 - Treated - RESAMPLE	F	8.0	23-Oct-17		
Killaloe - Sampling Complete											
Mackenzie CS											
Test Run of WFS	16-Jun-17	Craig Lance		S	5:50	Water Filling Station - Outside Main Office	S	<0.001	22-Jun-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
	17-Jun-17	Robin Remus		S	7:45	WFS Fountain -Outside Main Office	S	<0.001	22-Jun-17		
Day 1	15-Jun-17		10:15-11:15								
	16-Jun-17	Craig Lance	6:47	S	6:02	Rm 115	S	34.0	7-Jul-17	Out of Service & Investigate	Tap capped off July 27/2017 NFA
				F	6:51	Rm 115	F	40.0	7-Jul-17		
	16-Jun-17	Craig Lance	6:49	S	6:04	Rm 117 Art	S	<0.001	7-Jul-17		
				F	6:53	Rm 117 Art	F	<0.001	7-Jul-17		
Day 2 - MCS	04-Oct-17		10:15-11:15								
	05-Oct-17	Craig Lance	6:35	S	5:50	Rm 106C (1019)	S	<0.001	6-Nov-17		
				F	6:41	Rm 106C (1019)	F	0.0	6-Nov-17		
	05-Oct-17	Craig Lance	6:37	S	5:52	Main Office Tea Room (1003N)	S	3.0	6-Nov-17		
				F	6:42	Main Office Tea Room (1003N)	F	<0.001	6-Nov-17		
	05-Oct-17	Craig Lance	6:39	S	5:54	Fountain by Rm 125 (1124)	S	5.0	6-Nov-17		
				F	6:45	Fountain by Rm 125 (1124)	F	2.0	6-Nov-17		
Day 3 - MCS	16-Oct-17	Flush	10:15-11:15								
	17-Oct-17	Craig Lance	6:39	S	5:45	Rm 142 (1113A) Tap	S	6.0	6-Nov-17		
				F	6:35	Rm 142 (1113A) Tap	F	<0.001	6-Nov-17		
	17-Oct-17	Craig Lance	6:40	S	5:46	Rm 129 (1108b) Tap	S				
				F	6:36	Rm 129 (1108b) Tap	F				
	17-Oct-17	Craig Lance	6:41	S	5:47	Rm 131 (1107A) Tap	S	2.0	6-Nov-17		
				F	6:37	Rm 131 (1107A) Tap	F	1.0	6-Nov-17		
Day 4 - MCS	17-Oct-17		10:15-11:15								
	18-Oct-17	Craig Lance	6:39	S	5:45	Rm 148 (1105A) Tap	S	2.0	6-Nov-17		
				F	6:34	Rm 148 (1105A) Tap	F	<0.001	6-Nov-17		
	18-Oct-17	Craig Lance	6:40	S	5:46	Rm 133 (1101) Tap	S	<0.001	6-Nov-17		
				F	6:37	Rm 133 (1101) Tap	F	<0.001	6-Nov-17		
	18-Oct-17	Craig Lance	6:41	S	5:47	Rm 135 (1100) Tap	S	<0.001	6-Nov-17		
				F	6:36	Rm 135 (1100) Tap	F	<0.001	6-Nov-17		
Day 5 - MCS	18-Oct-17	Flush	10:15-11:15								
	19-Oct-17	Craig Lance	6:44	S	5:50	Rm 137 (1099) Tap	S	<0.001	13-Nov-17		
				F	6:39	Rm 137 (1099) Tap	F	<0.001	13-Nov-17		
	19-Oct-17	Craig Lance	6:45	S	5:51	Rm 139 (1096A) Tap	S	<0.001	13-Nov-17		
				F	6:41	Rm 139 (1096A) Tap	F	<0.001	13-Nov-17		
	19-Oct-17	Craig Lance	6:46	S	5:52	Rm 143 (1094) Tap	S	2.0	13-Nov-17		
				F	6:43	Rm 143 (1094) Tap	F	<0.001	13-Nov-17		
Day 6 - MCS	25-Oct-17	Flush	10:15-11:15								
	26-Oct-17	Craig Lance	6:39	S	5:54	Rm 158 (1090A) Tap	S	<0.001	13-Nov-17		
				F	6:43	Rm 158 (1090A) Tap	F	<0.001	13-Nov-17		
	26-Oct-17	Craig Lance	6:41	S	5:56	Rm 162 (1034A) Tap	S	<0.001	13-Nov-17		
				F	6:46	Rm 162 (1034A) Tap	F	<0.001	13-Nov-17		
	26-Oct-17	Craig Lance	6:44	S	5:59	Rm 160 (1083A) Tap	S	<0.001	13-Nov-17		
				F	6:44	Rm 160 (1083A) Tap	F	<0.001	13-Nov-17		
Day 7 - MCS	26-Oct-17	Flush	10:15-11:15								
	27-Oct-17	Craig Lance	6:28	S	5:43	Fountain by Rm 157 (1075)	S	<0.001	13-Nov-17		
				F	6:37	Fountain by Rm 157 (1075)	F	<0.001	13-Nov-17		
	27-Oct-17	Craig Lance	6:31	S	5:46	Fountain by Rm 155 (1037)	S	<0.001	13-Nov-17		
				F	6:39	Fountain by Rm 155 (1037)	F	<0.001	13-Nov-17		
	27-Oct-17	Craig Lance	6:33	S	5:49	Fountain by Rm 177 (1036)	S	<0.001	13-Nov-17		
				F	6:40	Fountain by Rm 177 (1036)	F	2.0	13-Nov-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
MCS-2/3 Complete											
Madawaska Valley DHS	05-Jun-17	Flush	5-Jun-17								
Day 1	06-Jun-17	Sherry Michaud	6:16	S	5:01	Rm 103 Play Sink	S	3.0	6-Jul-17		
				F	5:50	Rm 103 Play Sink	F	2.0	6-Jul-17		
MVDHS	06-Jun-17	Flush	6-Jun-17								
Day 2	07-Jun-17	Sherry Michaud	6:16	S	5:01	Rm 104	S	1.0	6-Jul-17		
				F	5:52	Rm 104	F	2.0	6-Jul-17		
	07-Jun-17	Sherry Michaud	6:16	S	5:01	Rm 107	S	2.0	6-Jul-17		
				F	5:53	Rm 107	F	<0.001	6-Jul-17		
MVDHS	07-Jun-17	Flush	7-Jun-17								
Day 3	08-Jun-17	Sherry Michaud	6:28	S	4:58	Rm 103 Adult Sink	S	3.0	11-Jul-17		
				F	5:48	Rm 103 Adult Sink	F	2.0	11-Jul-17		
	08-Jun-17	Sherry Michaud	6:26	S	4:56	Rm 304 Tap 2	S	1.0	6-Jul-17		
				F	5:50	Rm 304 Tap 2	F	<0.001	6-Jul-17		
MVDHS	08-Jun-17	Flush	8-Jun-17								
Day 4	09-Jun-17	Sherry Michaud	6:31	S	5:01	Rm 304 Tap 4	S	<0.001	6-Jul-17		
				F	5:54	Rm 304 Tap 4	F	<0.001	6-Jul-17		
	09-Jun-17	Sherry Michaud	6:35	S	5:05	Rm 101	S	<0.001	6-Jul-17		
				F	5:51	Rm 101	F	1.0	6-Jul-17		
MVDHS	12-Jun-17	Flush	12-Jun-17								
Day 5	13-Jun-17	Sherry Michaud	6:32	S	5:09	Rm 304 Tap 3	S	<0.001	6-Jul-17		
				F	5:54	Rm 304 Tap 3	F	<0.001	6-Jul-17		
MVDHS	13-Jun-17	Flush	13-Jun-17								
Day 6	14-Jun-17	Sherry Michaud	6:37	S	5:07	Small Sink Front Servery	S	6.0	6-Jul-17		
				F	5:53	Small Sink Front Servery	F	4.0	6-Jul-17		
	14-Jun-17	Sherry Michaud	6:37	S	5:07	Kitchen Sink 1	S	3.0	6-Jul-17		
				F	5:54	Kitchen Sink 1	F	4.0	6-Jul-17		
MVDHS	14-Jun-17	Flush	14-Jun-17								
Day 7	15-Jun-17	Sherry Michaud	6:31	S	5:01	Kitchen Sink 2	S	2.0	6-Jul-17		
				F	5:55	Kitchen Sink 2	F	2.0	6-Jul-17		
	15-Jun-17	Sherry Michaud	6:33	S	5:03	Boys Change Rm Fountain	S	2.0	6-Jul-17		
				F	5:52	Boys Change Rm Fountain	F	1.0	6-Jul-17		
	15-Jun-17	Sherry Michaud	6:36	S	5:06	Girls Change Rm Fountain	S	5.0	6-Jul-17		
				F	5:51	Girls Change Rm Fountain	F	3.0	6-Jul-17		
MVDHS	15-Jun-17	Flush	15-Jun-17								
Day 8	16-Jun-17	Sherry Michaud	6:24	S	4:56	Rm 116 Spec Ed Sink	S	1.0	10-Jul-17		
				F	5:48	Rm 116 Spec Ed Sink	F	1.0	10-Jul-17		
	16-Jun-17	Sherry Michaud	6:25	S	4:57	C Wing Fountain	S	7.0	10-Jul-17		
				F	5:47	C Wing Fountain	F	5.0	10-Jul-17		
	16-Jun-17	Sherry Michaud	6:26	S	4:58	Custodial Staff Sink	S	1.0	10-Jul-17		
				F	5:45	Custodial Staff Sink	F	1.0	10-Jul-17		
	16-Jun-17	Sherry Michaud	6:27	S	4:59	Staff Rm Sink	S	<0.001	10-Jul-17		
				F	5:45	Staff Rm Sink	F	<0.001	10-Jul-17		
MVDHS	19-Jun-17	Flush	19-Jun								
Day 9	20-Jun-17	Sherry Michaud	6:28	S	5:08	Rm 304 Tap 1	S	<0.001	10-Jul-17		
				F	5:55	Rm 304 Tap 1	F	<0.001	10-Jul-17		
	20-Jun-17	Sherry Michaud	6:31	S	5:11	2nd Floor WFS Fountain	S	<0.001	10-Jul-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
				F	5:58	2nd Floor WFS Fountain	F	<0.001	10-Jul-17		
MVDHS	20-Jun-17	Flush	20-Jun								
Day 9	21-Jun-17	Sherry Michaud	6:25	S	4:55	3rd Floor WFS Fountain	S	<0.001	10-Jul-17		
				F	5:44	3rd Floor WFS Fountain	F	<0.001	10-Jul-17		
MVDHS	21-Jun-17	Flush	21-Jun								
Day 10	22-Jun-17	Sherry Michaud	7:00	S	4:55	1st Flr WFS Fountain Boys ChgRm	S	<0.001	10-Jul-17		
				F	5:46	1st Flr WFS Fountain Boys ChgRm	F	<0.001	10-Jul-17		
	22-Jun-17	Sherry Michaud	7:03	S	4:58	1st Flr WFS Fountain C-Wing	S	<0.001	10-Jul-17		
				F	5:44	1st Flr WFS Fountain C-Wing	F	<0.001	10-Jul-17		
MVDHS	26-Sep-17		26-Sep								
Day 11	27-Sep-17	Sherry Michaud	6:20	S	5:05	Rm 109 Tap	S	1.0	13-Oct-17		
				F	6:02	Rm 109 Tap	F	1.0	13-Oct-17		
	27-Sep-17	Sherry Michaud	6:21	S	5:06	Rm 106 Tap	S	3.0	13-Oct-17		
				F	6:01	Rm 106 Tap	F	2.0	13-Oct-17		
	27-Sep-17	Sherry Michaud	6:22	S	5:07	Rm 105 Tap	S	3.0	13-Oct-17		
				F	6:00	Rm 105 Tap	F	4.0	13-Oct-17		
	27-Sep-17	Sherry Michaud	6:25	S	5:10	Fountain 2nd Floor	S	9.0	13-Oct-17		
				F	5:59	Fountain 2nd Floor	F	4.0	13-Oct-17		
MVDHS	28-Sep-17		28-Sep								
Day 12	29-Sep-17	Sherry Michaud	6:04	S	4:51	Rm 103 Small Sink	S	6.0	13-Oct-17		
				F	5:43	Rm 103 Small Sink	F	5.0	13-Oct-17		
	29-Sep-17	Sherry Michaud	6:08	S	4:55	Fountain 1st Flr	S	7.0	13-Oct-17		
				F	5:42	Fountain 1st Flr	F	4.0	13-Oct-17		
MVDHS	02-Oct-17	Flush	9:30-10:30								
Day 13	03-Oct-17	Sherry Michaud	6:38	S	5:08	Café Water Fountain	S	20.0	12-Oct-17	Out of Service & Investigate	Out of Service
				F	5:57	Café Water Fountain	F	12.0	12-Oct-17		Fountain source shut off- NFA
	03-Oct-17	Sherry Michaud	6:35	S	5:05	1st Floor WFS Fountain -Elementary	S	<0.001	13-Oct-17		
				F	5:52	1st Floor WFS Fountain -Elementary	F	<0.001	13-Oct-17		
MVDHS	03-Oct-17		03-Oct								
Day 14	04-Oct-17	Sherry Michaud	6:12	S	4:59	Fountain 3rd floor	S	7.0	13-Oct-17		
				F	5:46	Fountain 3rd floor	F	4.0	13-Oct-17		
MVDHS - Sampling Complete											
McNab	18-Jun-17	Flush	8:29-9:31								
Day 1	19-Jun-17	Donna McNulty	8:34	S	6:05	Room 1	S	1.0	18-Jul-17		
				F	7:03	Room 1	F	<0.001	18-Jul-17		
	19-Jun-17	Donna McNulty	8:35	S	6:06	Rm 4	S	2.0	18-Jul-17		
				F	7:02	Rm 4	F	4.0	18-Jul-17		
	19-Jun-17	Donna McNulty	8:36	S	6:07	Rm 7	S	<0.001	18-Jul-17		
				F	7:01	Rm 7	F	<0.001	18-Jul-17		
	19-Jun-17	Donna McNulty	8:37	S	6:08	Rm 12	S	2.0	18-Jul-17		
				F	7:00	Rm 12	F	<0.001	18-Jul-17		
	19-Jun-17	Donna McNulty	8:38	S	6:09	Rm 15	S	1.0	18-Jul-17		
				F	6:59	Rm 15	F	<0.001	18-Jul-17		
	19-Jun-17	Donna McNulty	8:39	S	6:10	Rm 17	S	<0.001	21-Jul-17		
				F	6:58	Rm 17	F	<0.001	21-Jul-17		
	19-Jun-17	Donna McNulty	8:40	S	6:11	Rm 18	S	<0.001	18-Jul-17		
				F	6:57	Rm 18	F	<0.001	18-Jul-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
McNab	19-Jun-17	Flush	8:15-9:17								
Day 2	20-Jun-17	Donna McNulty	8:43	S	6:00	Rm 11	S	2.0	18-Jul-17		
				F	6:54	Rm 11	F	3.0	18-Jul-17		
	20-Jun-17	Donna McNulty	8:44	S	6:01	Rm 13 Tap 1	S	<0.001	18-Jul-17		
				F	6:55	Rm 13 Tap 1	F	<0.001	18-Jul-17		
	20-Jun-17	Donna McNulty	8:44	S	6:01	Rm 11 - Tap 2	S	<0.001	21-Jul-17		
				F	6:55	Rm 11 - Tap 2	F	<0.001	21-Jul-17		
	20-Jun-17	Donna McNulty	8:45	S	6:02	Rm 16	S	1.0	21-Jul-17		
				F	6:56	Rm 16	F	<0.001	21-Jul-17		
	20-Jun-17	Donna McNulty	8:46	S	6:03	Rm 19	S	<0.001	21-Jul-17		
				F	6:57	Rm 19	F	<0.001	21-Jul-17		
	20-Jun-17	Donna McNulty	8:48	S	6:05	Rm 6	S	1.0	21-Jul-17		
				F	6:53	Rm 6	F	<0.001	21-Jul-17		
	20-Jun-17	Donna McNulty	8:49	S	6:06	Rm 3	S	2.0	21-Jul-17		
				F	6:52	Rm 3	F	<0.001	21-Jul-17		
McNab	20-Jun-17	Flush	7:05-8:20								
Day 3	21-Jun-17	Donna McNulty	9:41	S	6:01	Rm 11 Trough sink	S	<0.001	21-Jul-17		
				F	6:54	Rm 11 Trough Sink	F	3.0	21-Jul-17		
	21-Jun-17	Donna McNulty	9:42	S	6:02	Staff Room 10	S	1.0	21-Jul-17		
				F	6:54	Staff Room 10	F	<0.001	21-Jul-17		
	21-Jun-17	Donna McNulty	9:43	S	6:03	Rm 145C Kitchen Tap 1	S	2.0	21-Jul-17		
				F	6:53	Rm 145C Kitchen Tap 1	F	1.0	21-Jul-17		
	21-Jun-17	Donna McNulty	9:43	S	6:03	Rm 145C Kitchen Tap 2	S	2.0	21-Jul-17		
				F	6:53	Rm 145C Kitchen Tap 2	F	2.0	21-Jul-17		
	21-Jun-17	Donna McNulty	9:43	S	6:03	Rm 5 Fountain	S	<0.001	21-Jul-17		
				F	6:52	Rm 5 Fountain	F	<0.001	21-Jul-17		
	21-Jun-17	Donna McNulty	9:44	S	6:04	Rm 2 Fountain	S	3.0	21-Jul-17		
				F	6:51	Rm 2 Fountain	F	<0.001	21-Jul-17		
McNab	21-Jun-17	Flush	21-Jun								
Day 4	22-Jun-17	Donna McNulty	9:40	S	5:56	Rm 9 Fountain	S	2.0	21-Jul-17		
				F	6:54	Rm 9 Fountain	F	1.0	21-Jul-17		
	22-Jun-17	Donna McNulty	9:41	S	5:57	Rm 12 Fountain	S	2.0	21-Jul-17		
				F	6:55	Rm 12 Fountain	F	<0.001	21-Jul-17		
	22-Jun-17	Donna McNulty	9:42	S	5:58	Rm 16 Fountain	S	2.0	21-Jul-17		
				F	6:56	Rm 16 Fountain	F	<0.001	21-Jul-17		
	22-Jun-17	Donna McNulty	9:43	S	5:59	Rm 18 Fountain	S	1.0	21-Jul-17		
				F	6:57	Rm 18 Fountain	F	<0.001	21-Jul-17		
	22-Jun-17	Donna McNulty	9:45	S	6:01	Rm 6 Fountain	S	2.0	21-Jul-17		
				F	6:53	Rm 6 Fountain	F	<0.001	21-Jul-17		
	22-Jun-17	Donna McNulty	9:47	S	6:03	Rm 5 Fountain	S	1.0	21-Jul-17		
				F	6:52	Rm 5 Fountain	F	<0.001	21-Jul-17		
	22-Jun-17	Donna McNulty	9:50	S	6:05	Rm 2 Fountain	S	2.0	21-Jul-17		
				F	6:51	Rm 2 Fountain	F	<0.001	21-Jul-17		
McNab	22-Jun-17	Flush	22-Jun								
Day 5	23-Jun-17	Donna McNulty	9:49	S	6:04	Rm 19 Fountain	S	1.0	21-Jul-17		
				F	7:05	Rm 19 Fountain	F	<0.001	21-Jul-17		
	23-Jun-17	Donna McNulty	9:50	S	6:05	Fountain by Custodial Office	S	<0.001	21-Jul-17		
				F	7:04	Fountain by Custodial Office	F	<0.001	21-Jul-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
	23-Jun-17	Donna McNulty	9:51	S	6:06	Fountain between Washrooms	S	<0.001	21-Jul-17		
				F	7:03	Fountain between Washrooms	F	<0.001	21-Jul-17		
	23-Jun-17	Donna McNulty	9:54	S	6:09	Rm 7 Fountain	S	1.0	21-Jul-17		
				F	7:02	Rm 7 Fountain	F	<0.001	21-Jul-17		
	23-Jun-17	Donna McNulty	9:55	S	6:10	Rm 4 Fountain	S	3.0	21-Jul-17		
				F	7:01	Rm 4 Fountain	F	1.0	21-Jul-17		
	23-Jun-17	Donna McNulty	9:56	S	6:11	Rm 3 Fountain	S	2.0	21-Jul-17		
				F	7:00	Rm 3 Fountain	F	<0.001	21-Jul-17		
	23-Jun-17	Donna McNulty	9:57	S	6:12	Rm 1 Fountain	S	2.0	21-Jul-17		
				F	7:00	Rm 1 Fountain	F	<0.001	21-Jul-17		
McNab - Sampling Complete											
OHS	19-Jun-17	Flush	19-Jun-17								
Day 1	20-Jun-17	M. Lippert	6:34	S	5:19	Rm 1079 Tap 1	S	2.0	10-Jul-17		
				F	6:16	Rm 1079 Tap 1	F	<0.001	10-Jul-17		
	20-Jun-17	M. Lippert	6:37	S	5:22	Caf Kitchen Tap 1	S	12.0	9-Jul-17	Daily Flushing	Daily flushing of tap
				F	6:18	Caf Kitchen Tap 1	F	4.0	9-Jul-17		
OHS	20-Jun-17	Flush	9:45-10:45								
Day 2	21-Jun-17	M. Lippert	6:48	S	5:18	Fountain Boys Change Rm	S	3.0	9-Jul-17	Out of Service & Investigate	Tap capped off - out of service
				F	6:13	Fountain Boys Change Rm	F	20.0	9-Jul-17		NFA
	21-Jun-17	M. Lippert	6:51	S	5:21	Cafeteria Kitchen Tap #2	S	25.0	9-Jul-17	Daily Flushing	Daily flushing of tap
				F	6:15	Cafeteria Kitchen Tap #2	F	7.0	9-Jul-17		
	21-Jun-17	M. Lippert	6:41	S	5:11	Library Office Sink	S	4.0	10-Jul-17		
				F	6:08	Library Office Sink	F	2.0	10-Jul-17		
	21-Jun-17	M. Lippert	6:46	S	5:16	Staffroom Kitchen Sink	S	2.0	10-Jul-17		
				F	6:10	Staffroom Kitchen Sink	F	<0.001	10-Jul-17		
OHS	21-Jun-17	Flush	9-10:00								
Day 3	22-Jun-17	M. Lippert	7:18	S	5:18	Fountain by Rm 1088	S	2.0	10-Jul-17		
				F	6:15	Fountain by Rm 1088	F	<0.001	10-Jul-17		
	22-Jun-17	M. Lippert	7:20	S	5:20	Photo Copy Rm Sink	S	3.0	11-Jul-17		
				F	6:17	Photo Copy Rm Sink	F	2.0	10-Jul-17		
OHS	22-Jun-17	Flush	7-8:00								
Day 4	23-Jun-17	M. Lippert	9:03	S	5:03	Caf Kitchen Tap 4	S	4.0	11-Jul-17		
				F	6:07	Caf Kitchen Tap 4	F	2.0	11-Jul-17		
	23-Jun-17	M. Lippert	9:07	S	5:07	Rm 1079 Tap 4 Home Ec	S	4.0	11-Jul-17		
				F	6:09	Rm 1079 Tap 4 Home Ec	F	1.0	11-Jul-17		
	23-Jun-17	M. Lippert	9:13	S	5:13	Fountain by Rm 2009	S	<0.001	11-Jul-17		
				F	6:15	Fountain by Rm 2009	F	<0.001	11-Jul-17		
	23-Jun-17	M. Lippert	9:19	S	5:19	Rm 1095 Old Nurses Rm	S	9.0	11-Jul-17		
				F	6:20	Rm 1095 Old Nurses Rm	F	4.0	11-Jul-17		
OHS	26-Jun-17	Flush	7-8:00								
Day 5	27-Jun-17	M. Lippert	9:08	S	5:08	Cafeteria Kitchen Sink # 5	S	2.0	18-Jul-17		
				F	6:08	Cafeteria Kitchen Sink # 5	F	<0.001	18-Jul-17		
	27-Jun-17	M. Lippert	9:16	S	5:16	Rm 2008 Sink	S	9.0	18-Jul-17		
				F	6:11	Rm 2008 Sink	F	4.0	18-Jul-17		
	27-Jun-17	M. Lippert	9:18	S	5:18	Rm 2015 Sink Dept Head	S	2.0	18-Jul-17		
				F	6:12	Rm 2015 Sink Dept Head	F	<0.001	18-Jul-17		
	27-Jun-17	M. Lippert	9:19	S	5:19	Rm 2005 Sink	S	4.0	18-Jul-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
				F	6:13	Rm 2005 Sink	F	1.0	18-Jul-17		
	27-Jun-17	M. Lippert	9:20	S	5:20	Rm 2004 Sink	S	4.0	18-Jul-17		
				F	6:14	Rm 2004 Sink	F	1.0	18-Jul-17		
OHS - Day 6	02-Oct-17	Flush	9:30-10:30								
	03-Oct-17	M. Lippert	6:37	S	5:07	Fountain by Rm 1056 CoOp	S	<0.001	12-Oct-17		
				F	6:04	Fountain by Rm 1056 CoOp	F	<0.001	12-Oct-17		
	03-Oct-17	M. Lippert	6:40	S	5:10	Fountain Outside Rm 1062 Weight Rm	S	<0.001	13-Oct-17		
				F	6:05	Fountain Outside Rm 1062 Weight Rm	F	<0.001	13-Oct-17		
	03-Oct-17	M. Lippert	6:43	S	5:13	Fountain by Rm 1079	S	<0.001	12-Oct-17		
				F	6:06	Fountain by Rm 1079	F	<0.001	12-Oct-17		
	03-Oct-17	M. Lippert	6:45	S	5:15	Tap 2 Rm 1079 Home Ec	S	2.0	13-Oct-17		
				F	6:09	Tap 2 Rm 1079 Home Ec	F	1.0	13-Oct-17		
	03-Oct-17	M. Lippert	6:47	S	5:17	Fountain by Guidance Rm 1093	S	<0.001	12-Oct-17		
				F	6:12	Fountain by Guidance Rm 1093	F	<0.001	12-Oct-17		
OHS Day 7	03-Oct-17	Flush	9:30-10:30								
	04-Oct-17	M. Lippert	6:31	S	5:01	Cafeteria Kitchen Tap 3	S	1.0	11-Oct-17		
				F	6:02	Cafeteria Kitchen Tap 3	F	<0.001	11-Oct-17		
	04-Oct-17	M. Lippert	6:33	S	5:03	Fountain Outside Woodshop Rm 1030	S	2.0	11-Oct-17		
				F	6:03	Fountain Outside Woodshop Rm 1030	F	1.0	11-Oct-17		
	04-Oct-17	M. Lippert	6:35	S	5:05	Tap 3 Home Ec Rm 1079	S	2.0	11-Oct-17		
				F	6:05	Tap 3 Home Ec Rm 1079	F	<0.001	11-Oct-17		
	04-Oct-17	M. Lippert	6:38	S	5:08	Music Rm 0015 Sink	S	1.0	11-Oct-17		
				F	6:07	Music Rm 0015 Sink	F	<0.001	11-Oct-17		
	04-Oct-17	M. Lippert	6:42	S	5:12	Fountain by Rm 2004	S	1.0	11-Oct-17		
				F	6:09	Fountain by Rm 2004	F	<0.001	11-Oct-17		
OHS - Sampling Complete											
Palmer Rapids Day 1	07-Jun-17	Flushed	7-Jun-17								
	08-Jun-17	Tony Yandernoll	13:25	S	5:55	Kindergarden Rm	S	2.0	22-Jun-17		
				F	6:58	Kindergarden Rm	F	<0.001	22-Jun-17		
	08-Jun-17	Tony Yandernoll	13:28	S	5:58	Room 9 - Fountain	S	3.0	22-Jun-17		
				F	7:03	Room 9 - Fountain	F	1.0	22-Jun-17		
	08-Jun-17	Tony Yandernoll	13:32	S	6:02	Room 8 - Fountain	S	3.0	22-Jun-17		
				F	7:05	Room 8 - Fountain	F	1.0	22-Jun-17		
	08-Jun-17	Tony Yandernoll	13:35	S	6:05	Room 7 - Fountain	S	3.0	22-Jun-17		
				F	7:07	Room 7 - Fountain	F	1.0	22-Jun-17		
	08-Jun-17	Tony Yandernoll	13:38	S	6:08	Hall Fountain	S	2.0	22-Jun-17		
				F	7:09	Hall Fountain	F	<0.001	22-Jun-17		
Palmer Rapids Day 2	08-Jun-17	Flushed	8-Jun-17								
	09-Jun-17	Tony Yandernoll	13:32	S	6:02	Room 6 - Fountain	S	2.0	22-Jun-17		
				F	6:58	Room 6 - Fountain	F	1.0	22-Jun-17		
	09-Jun-17	Tony Yandernoll	13:35	S	6:05	Room 5 - Fountain	S	4.0	22-Jun-17		
				F	6:59	Room 5 - Fountain	F	2.0	22-Jun-17		
	09-Jun-17	Tony Yandernoll	13:37	S	6:07	Room 2 - Fountain	S	8.0	22-Jun-17		
				F	7:00	Room 2 - Fountain	F	4.0	22-Jun-17		
	09-Jun-17	Tony Yandernoll	13:39	S	6:09	Room 4 - Fountain	S	2.0	22-Jun-17		
				F	7:01	Room 4 - Fountain	F	<0.001	22-Jun-17		
	09-Jun-17	Tony Yandernoll	13:41	S	6:11	Rm 1 Fountain	S	2.0	6-Jul-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
				F	7:02	Rm 1 Fountain	F	1.0	6-Jul-17		
Palmer Rapids	12-Jun-17	Flushed	12-Jun-17								
Day 3	13-Jun-17	Tony Yandernoll	13:33	S	6:03	Rm 9 Tap	S	3.0	6-Jul-17		
				F	6:55	Rm 9 Tap	F	2.0	6-Jul-17		
	13-Jun-17	Tony Yandernoll	13:34	S	6:04	Rm 8 Tap	S	4.0	6-Jul-17		
				F	6:56	Rm 8 Tap	F	2.0	6-Jul-17		
	13-Jun-17	Tony Yandernoll	13:36	S	6:06	Rm 7 Tap	S	3.0	6-Jul-17		
				F	6:57	Rm 7 Tap	F	1.0	6-Jul-17		
	13-Jun-17	Tony Yandernoll	13:37	S	6:07	Rm 6 Tap	S	3.0	6-Jul-17		
				F	6:58	Rm 6 Tap	F	1.0	6-Jul-17		
	13-Jun-17	Tony Yandernoll	13:39	S	6:09	Kitchen Tap 1	S	7.0	6-Jul-17		
				F	6:59	Kitchen Tap 1	F	4.0	6-Jul-17		
Palmer Rapids	13-Jun-17	Flushed	13-Jun-17								
Day 4	14-Jun-17	Tony Yandernoll	13:20	S	5:50	Room 5 Tap	S	4.0	6-Jul-17		
				F	6:43	Room 5 Tap	F	2.0	6-Jul-17		
	14-Jun-17	Tony Yandernoll	13:21	S	5:51	Kitchen Tap 2	S	12.0	5-Jul-17	Daily Flush	Daily flush of tap
				F	6:44	Kitchen Tap 2	F	4.0	5-Jul-17		
	14-Jun-17	Tony Yandernoll	13:23	S	5:53	Rm 2 Tap	S	5.0	6-Jul-17		
				F	6:45	Rm 2 Tap	F	2.0	6-Jul-17		
	14-Jun-17	Tony Yandernoll	13:24	S	5:54	Rm 4 Tap	S	1.0	6-Jul-17		
				F	6:46	Rm 4 Tap	F	<0.001	6-Jul-17		
	14-Jun-17	Tony Yandernoll	13:26	S	5:56	Rm 3 Tap	S	2.0	6-Jul-17		
				F	6:47	Rm 3 Tap	F	1.0	6-Jul-17		
Palmer Rapids	14-Jun-17	Flushed	14-Jun-17								
Day 5	15-Jun-17	Tony Yandernoll	13:10	S	5:40	Staffroom	S	<0.001	6-Jul-17		
				F	6:30	Staffroom	F	<0.001	6-Jul-17		
	15-Jun-17	Tony Yandernoll	13:11	S	5:41	Rm 1 Tap	S	2.0	6-Jul-17		
				F	6:31	Rm 1 Tap	F	<0.001	6-Jul-17		
	15-Jun-17	Tony Yandernoll	13:13	S	5:43	Office	S	6.0	6-Jul-17		
				F	6:32	Office	F	4.0	6-Jul-17		
Palmer - Sampling Complete											
Pine View PS	07-Jun-17	Flushed	07-Jun								
Day 1	08-Jun-17	Marc McCulloch	13:04	S	6:04	Resource Rm	S	74.0	30-Jun-17	Out of Service - Investigate	Tap capped off - out of service
				F	7:00	Resource Rm	F	73.0	30-Jun-17		NFA
	08-Jun-17	Marc McCulloch	13:06	S	6:06	Rm 102 - Tap 1	S	4.0	30-Jun-17	Out of Service - Investigate	Faucet changed - Resample
				F	7:01	Rm 102 - Tap 1	F	14.0	30-Jun-17		Resample Oct 17 - Resolved
	08-Jun-17	Marc McCulloch	13:07	S	6:07	Rm 104 - Tap 1	S	2.0	5-Jul-17		
				F	7:02	Rm 104 - Tap 1	F	<0.001	5-Jul-17		
	08-Jun-17	Marc McCulloch	13:08	S	6:08	Rm 114 - Tap 1	S	10.0	5-Jul-17		
				F	7:02	Rm 114 - Tap 1	F	2.0	5-Jul-17		
	08-Jun-17	Marc McCulloch	13:10	S	6:10	Rm 117	S	6.0	5-Jul-17		
				F	7:03	Rm 117	F	2.0	5-Jul-17		
	08-Jun-17	Marc McCulloch	13:11	S	6:11	Rm 118 - Tap 1	S	40.0	30-Jun-17	Out of Service - Investigate	Faucet changed - Resample
				F	7:04	Rm 118 - Tap 1	F	16.0	30-Jun-17		Resample Oct 17 - Resolved
Pine View PS	12-Jun-17	Flushed	12-Jun								
Day 2	13-Jun-17	Marc McCulloch	13:20	S	6:20	Rm 115	S	12.0	4-Jul-17	Daily Flush	Daily flush of tap
				F	7:14	Rm 115	F	5.0	4-Jul-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
	13-Jun-17	Marc McCulloch	13:21	S	6:21	Rm 102 - Tap 2-F	S	8.0	5-Jul-17		
				F	7:14	Rm 102 - Tap 2-F	F	3.0	5-Jul-17		
	13-Jun-17	Marc McCulloch	13:25	S	6:25	Rm 114 - Tap 2-F	S	12.0	4-Jul-17	Out of Service - Investigate	Tap capped off - out of service NFA
				F	7:16	Rm 114 - Tap 2-F	F	27.0	4-Jul-17		
	13-Jun-17	Marc McCulloch	13:27	S	6:27	Rm 118 - Tap 2-F	S	9.0	5-Jul-17		
				F	7:18	Rm 118 - Tap 2-F	F	3.0	5-Jul-17		
Pine View PS	13-Jun-17	Flushed	13-Jun								
Day 3	14-Jun-17	Marc McCulloch	13:19	S	6:19	Rm 103 - Tap 1	S	3.0	6-Jul-17		
				F	7:10	Rm 103 - Tap 1	F	1.0	6-Jul-17		
	14-Jun-17	Marc McCulloch	13:20	S	6:20	Rm 105 Tap 1	S	12.0	5-Jul-17	Daily Flush	Daily flush of tap
				F	7:11	Rm 105 Tap 1	F	3.0	5-Jul-17		
	14-Jun-17	Marc McCulloch	13:21	S	6:21	Library Office Tap 1	S	16.0	5-Jul-17	Daily Flush	Daily flush of tap
				F	7:11	Library Office Tap 1	F	4.0	5-Jul-17		
	14-Jun-17	Marc McCulloch	13:23	S	6:23	Kitchen Tap 1	S	27.0	5-Jul-17	Out of Service - Investigate	Faucet changed - Resample Resample Oct 17 - Flush Daily
				F	7:12	Kitchen Tap 1	F	17.0	5-Jul-17		
	14-Jun-17	Marc McCulloch	13:24	S	6:24	Rm 106 - Tap 1	S	7.0	6-Jul-17		
				F	7:13	Rm 106 - Tap 1	F	3.0	6-Jul-17		
Pine View PS	14-Jun-17	Flushed	14-Jun								
Day 4	15-Jun-17	Marc McCulloch	13:20	S	6:20	Rm 103 Tap 2-F	S	10.0	6-Jul-17		
				F	7:10	Rm 103 Tap 2-F	F	4.0	6-Jul-17		
	15-Jun-17	Marc McCulloch	13:21	S	6:21	Rm 105 Tap 2	S	4.0	6-Jul-17		
				F	7:11	Rm 105 Tap 2	F	<0.001	6-Jul-17		
	15-Jun-17	Marc McCulloch	13:22	S	6:22	Kitchen Tap 2	S	4.0	10-Jul-17		
				F	7:11	Kitchen Tap 2	F	1.0	10-Jul-17		
Pine View PS	15-Jun-17	Flushed	15-Jun								
Day 5	16-Jun-17	Marc McCulloch	13:16	S	6:16	Rm 105 Tap 3	S	2.0	10-Jul-17		
				F	7:06	Rm 105 Tap 3	F	<0.001	10-Jul-17		
	16-Jun-17	Marc McCulloch	13:17	S	6:17	Rm 111 Tap 1	S	2.0	10-Jul-17		
				F	7:07	Rm 111 Tap 1	F	<0.001	10-Jul-17		
	16-Jun-17	Marc McCulloch	13:19	S	6:19	Rm 110 Tap 1	S	5.0	10-Jul-17		
				F	7:07	Rm 110 Tap 1	F	1.0	10-Jul-17		
	16-Jun-17	Marc McCulloch	13:20	S	6:20	Rm 109 Tap 1	S	5.0	10-Jul-17		
				F	7:08	Rm 109 Tap 1	F	2.0	10-Jul-17		
Pine View PS	20-Jun-17	Flushed	20-Jun								
Day 6	21-Jun-17	Marc McCulloch	13:23	S	6:23	Fountain Office Hall	S	<0.001	10-Jul-17		
				F	7:16	Fountain Office Hall	F	<0.001	10-Jul-17		
	21-Jun-17	Marc McCulloch	13:25	S	6:25	Rm 111 Tap 2-F	S	4.0	10-Jul-17		
				F	7:19	Rm 111 Tap 2-F	F	1.0	10-Jul-17		
	21-Jun-17	Marc McCulloch	13:27	S	6:27	Rm 110 Tap 2-F	S	2.0	10-Jul-17		
				F	7:19	Rm 110 Tap 2-F	F	1.0	10-Jul-17		
	21-Jun-17	Marc McCulloch	13:29	S	6:29	Rm 109 Tap 2-F	S	3.0	10-Jul-17		
				F	7:20	Rm 109 Tap 2-F	F	<0.001	10-Jul-17		
	21-Jun-17	Marc McCulloch	13:30	S	6:30	Staff Rm	S	<0.001	10-Jul-17		
				F	7:20	Staff Rm	F	<0.001	10-Jul-17		
Pine View PS	16-Oct-17	Flushed	16-Oct								
Day 7	17-Oct-17	Marc McCulloch	13:36	S	6:36	Rm 118 Tap 1 RESAMPLE	S	9.0	6-Nov-17	Resolved	Resolved
				F	7:27	Rm 118 Tap 1 RESAMPLE	F	3.0	6-Nov-17		
	17-Oct-17	Marc McCulloch	13:38	S	6:38	Rm 102 Tap 1 RESAMPLE	S	8.0	6-Nov-17	Resolved	Resolved

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
				F	7:29	Rm 102 Tap 1 RESAMPLE	F	2.0	6-Nov-17		
	17-Oct-17	Marc McCulloch	13:40	S	6:40	Fountain by Library	S	<0.001	6-Nov-17		
				F	7:30	Fountain by Library	F	<0.001	6-Nov-17		
	17-Oct-17	Marc McCulloch	13:41	S	6:41	Kitchen Tap 1 RESAMPLE	S	22.0	24-Oct-17	Daily Flushing	Daily Flushing
				F	7:31	Kitchen Tap 1 RESAMPLE	F	6.0	24-Oct-17		
Pine View Sampling Complete											
Queen Elizabeth											
	13-Jun-17	Flush	13-Jun-17								
Day 1	14-Jun-17	V. Verdon	10:10	S	6:00	Rm 6 (138) - Tap 1	S	22.0	4-Jul-17	Daily Flushing	Daily flush of tap
				F	6:58	Rm 6 (138) - Tap 1	F	<1	4-Jul-17		
	14-Jun-17	V. Verdon	10:11	S	6:01	Rm 8 (135)	S	64.0	4-Jul-17	Out of Service & Investigate	Taps replaced
				F	6:57	Rm 8 (135)	F	217.0	4-Jul-17		Resampled Aug 9/17 - Resolved
	14-Jun-17	V. Verdon	10:13	S	6:03	Rm 4 (141)	S	2.0	5-Jul-17		
				F	6:56	Rm 4 (141)	F	<0.001	5-Jul-17		
	14-Jun-17	V. Verdon	10:15	S	6:05	Rm 10 (133)	S	20.0	4-Jul-17	Daily Flushing	Daily flush of tap
				F	6:55	Rm 10 (133)	F	4.0	4-Jul-17		
	14-Jun-17	V. Verdon	10:18	S	6:08	Rm 144 Kitchen	S	5.0	5-Jul-17		
				F	6:54	Rm 144 Kitchen	F	1.0	5-Jul-17		
Day 2 - QE	14-Jun-17	Flush	14-Jun-17								
	15-Jun-17	V. Verdon	10:07	S	5:57	Rm 5 (140)	S	3.0	6-Jul-17		
				F	6:48	Rm 5 (140)	F	1.0	6-Jul-17		
	15-Jun-17	V. Verdon	10:09	S	5:59	Rm 9 (134)	S	7.0	5-Jul-17	Out of Service & Investigate	Taps replaced
				F	6:49	Rm 9 (134)	F	37.0	5-Jul-17		Resampled Aug 9/17 - Dially flush
	15-Jun-17	V. Verdon	10:11	S	6:01	Rm 1 (113)	S	13.0	5-Jul-17	Daily Flushing	Daily flush of tap
				F	6:49	Rm 1 (113)	F	4.0	5-Jul-17		
	15-Jun-17	V. Verdon	10:12	S	6:02	Rm 2 (112)	S	3.0	6-Jul-17		
				F	6:50	Rm 2 (112)	F	1.0	6-Jul-17		
Day 3 - QE	15-Jun-17	Flush	15-Jun				S				
	16-Jun-17	V. Verdon	10:09	S	5:59	Rm 124 Staffroom	S	2.0	14-Jul-17		
				F	6:48	Rm 124 Staffroom	F	<0.001	14-Jul-17		
	16-Jun-17	V. Verdon	10:10	S	6:00	Rm 16 (123)	S	2.0	14-Jul-17		
				F	6:49	Rm 16 (123)	F	1.0	14-Jul-17		
	16-Jun-17	V. Verdon	10:10	S	6:00	Rm 13 (121)	S	3.0	14-Jul-17		
				F	6:49	Rm 13 (121)	F	1.0	14-Jul-17		
	16-Jun-17	V. Verdon	10:11	S	6:01	Rm 11 (131)	S	<0.001	14-Jul-17		
				F	6:50	Rm 11 (131)	F	<0.001	14-Jul-17		
	16-Jun-17	V. Verdon	10:12	S	6:02	Rm 15 (129)	S	1.0	14-Jul-17		
				F	6:50	Rm 15 (129)	F	<0.001	14-Jul-17		
Day 4 - QE	21-Jun-17	Flush	6:50-7:50								
	22-Jun-17	V. Verdon	10:10	S	6:00	WFS Fountain Hall 119	S	<0.001	14-Jul-17		
				F	6:56	WFS Fountain Hall 119	F	<0.001	14-Jul-17		
	22-Jun-17	V. Verdon	10:12	S	6:02	Rm 11 (131) Tap 2	S	2.0	14-Jul-17		
				F	6:57	Rm 11 (131) Tap 2	F	<0.001	14-Jul-17		
	22-Jun-17	V. Verdon	10:14	S	6:04	Rm 14 (128) Fountain	S	1.0	14-Jul-17		
				F	6:57	Rm 14 (128) Fountain	F	<0.001	14-Jul-17		
	22-Jun-17	V. Verdon	10:18	S	6:08	WFS Fountain Hall 110	S	<0.001	14-Jul-17		
				F	6:59	WFS Fountain Hall 110	F	<0.001	14-Jul-17		
	22-Jun-17	V. Verdon	10:16	S	6:06	Rm 12 (130) Fountain	S	1.0	14-Jul-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
				F	6:58	Rm 12 (130) Fountain	F	<0.001	14-Jul-17		
Day 5 - QE	22-Jun-17	Flush	6:50-7:50								
	23-Jun-17	V. Verdon	10:04	S	5:54	Rm 137B Sink	S	2.0	14-Jul-17		
				F	6:48	Rm 137B Sink	F	<0.001	14-Jul-17		
	23-Jun-17	V. Verdon	10:06	S	5:56	WFS Fountain Rm 136	S	<0.001	14-Jul-17		
				F	6:48	WFS Fountain Rm 136	F	<0.001	14-Jul-17		
	23-Jun-17	V. Verdon	10:09	S	5:59	Rm 12 (130) Sink	S	1.0	14-Jul-17		
				F	6:50	Rm 12 (130) Sink	F	<0.001	14-Jul-17		
	23-Jun-17	V. Verdon	10:10	S	6:00	Rm 14 (128) Sink	S	1.0	14-Jul-17		
				F	6:50	Rm 14 (128) Sink	F	<0.001	14-Jul-17		
	23-Jun-17	V. Verdon	10:11	S	6:01	Fountain Hall 119	S	1.0	14-Jul-17		
				F	6:52	Fountain Hall 119	F	<0.001	14-Jul-17		
Day 6 - QE	29-Jun-17	Flush	6:50-7:50								
	30-Jun-17	V. Verdon	10:19	S	6:09	Rm 131 (11) Fountain	S	1.0	14-Jul-17		
				F	6:55	Rm 131 (11) Fountain	F	<0.001	14-Jul-17		
Day 7 - QE	08-Aug-17	Flush	2:15-3:15								
	09-Aug-17	V. Verdon	13:02	S	6:17	Rm 9 - Resample	S	16.0	21-Aug-17	Daily Flushing	Daily Flush of tap
				F	7:05	Rm 9 - Resample	F	4.0	21-Aug-17		
	09-Aug-17	V. Verdon	13:04	S	6:19	Rm 8 - Resample	S	5.0	21-Aug-17	Resolved	Resolved - NFA
				F	7:06	Rm 8 - Resample	F	2.0	21-Aug-17		
Queen E - Sampling Complete											
Renfrew Collegiate	22-Jun-17		10-11:00								
Day 1	23-Jun-17	B. Code	6:00	S	5:00	Rm 1041 Culinary Tap 1	S	2.0	18-Jul-17		
				F	5:46	Rm 1041 Culinary Tap 1	F	1.0	18-Jul-17		
Day 2 - RCI	26-Jun-17		10-11:00								
	27-Jun-17	B. Code	6:00	S	5:00	Rm 1028 Music	S	4.0	18-Jul-17		
				F	5:46	Rm 1028 Music	F	2.0	18-Jul-17		
	27-Jun-17	B. Code	6:03	S	5:03	Rm 1008 Vocational Rm	S	2.0	18-Jul-17		
				F	5:55	Rm 1008 Vocational Rm	F	<0.001	18-Jul-17		
	27-Jun-17	B. Code	6:04	S	5:04	Rm 1041 Culinary Tap #2	S	2.0	17-Jul-17		
				F	5:56	Rm 1041 Culinary Tap #2	F	1.0	17-Jul-17		
	27-Jun-17	B. Code	6:06	S	5:05	Rm 1047 Staff Rm	S	3.0	18-Jul-17		
				F	5:57	Rm 1047 Staff Rm	F	1.0	18-Jul-17		
Day 3 - RCI	27-Jun-17	Flush	10-11:00								
	28-Jun-17	B. Code	6:02	S	5:02	Room 1045A Cafeteria Kitchen	S	4.0	18-Jul-17		
				F	5:54	Room 1045A Cafeteria Kitchen	F	1.0	18-Jul-17		
	28-Jun-17	B. Code	6:04	S	5:04	Room 1041 Culinary Tap # 3	S	2.0	18-Jul-17		
				F	5:56	Room 1041 Culinary Tap # 3	F	1.0	18-Jul-17		
	28-Jun-17	B. Code	6:05	S	5:05	Rm 1054A Water Fountain	S	<0.001	18-Jul-17		
				F	5:57	Rm 1054A Water Fountain	F	<0.001	18-Jul-17		
	28-Jun-17	B. Code	6:00	S	5:00	Water Fountain Rm 1003	S	<0.001	14-Jul-17		
				F	5:46	Water Fountain Rm 1003	F	<0.001	14-Jul-17		
	28-Jun-17	B. Code	6:03	S	5:03	1067 Music Rm	S	<0.001	14-Jul-17		
				F	5:55	1067 Music Rm	F	<0.001	14-Jul-17		
Day 4 - RCI	28-Jun-17	Flush	10-11:00								
	29-Jun-17	B. Code	6:01	S	5:01	Rm 1015A Water Fountain	S	<0.001	14-Jul-17		
				F	5:53	Rm 1015A Water Fountain	F	<0.001	14-Jul-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
	29-Jun-17	B. Code	6:02	S	5:02	Rm 1007A Water Fountain	S	<0.001	14-Jul-17		
				F	5:54	Rm 1007A Water Fountain	F	<0.001	14-Jul-17		
	29-Jun-17	B. Code	6:03	S	5:03	Rm 1002 Water Fountain	S	<0.001	17-Jul-17		
				F	5:55	Rm 1002 Water Fountain	F	<0.001	17-Jul-17		
	29-Jun-17	B. Code	6:04	S	5:04	Rm 1041 Culinary Tap # 4	S	2.0	14-Jul-17		
				F	5:56	Rm 1041 Culinary Tap # 4	F	2.0	14-Jul-17		
	29-Jun-17	B. Code	6:05	S	5:05	Rm 1046 Water Fountain	S	<0.001	18-Jul-17		
				F	5:57	Rm 1046 Water Fountain	F	0.0	18-Jul-17		
Day 5 - RCI	26-Oct-17	Flush	26-Oct-17								
	27-Oct-17	P. Bromley	6:00	S	5:00	Spec Ed Rm 2025 Tap	S	3.0	6-Nov-17		
				F	6:00	Spec Ed Rm 2025 Tap	F	1.0	6-Nov-17		
	27-Oct-17	P. Bromley	6:01	S	5:01	Fountain Outside Library	S	<0.001	6-Nov-17		
				F	6:01	Fountain Outside Library	F	<0.001	6-Nov-17		
	27-Oct-17	P. Bromley	6:02	S	5:02	Fountain Outside Rm 21410	S	<0.001	6-Nov-17		
				F	6:02	Fountain Outside Rm 21410	F	<0.001	6-Nov-17		
	27-Oct-17	P. Bromley	6:03	S	5:03	Fountain Outside Rm 216	S	<0.001	6-Nov-17		
				F	6:03	Fountain Outside Rm 216	F	<0.001	6-Nov-17		
	27-Oct-17	P. Bromley	6:06	S	5:06	Fountain Outside Rm 201	S	<0.001	6-Nov-17		
				F	6:05	Fountain Outside Rm 201	F	<0.001	6-Nov-17		
	27-Oct-17	P. Bromley	6:07	S	5:07	Fountain Outside Rm 301	S	2.0	6-Nov-17		
				F	6:07	Fountain Outside Rm 301	F	1.0	6-Nov-17		
	27-Oct-17	P. Bromley	6:10	S	5:10	Fountain Outside Rm 312	S	<0.001	6-Nov-17		
				F	6:09	Fountain Outside Rm 312	F	<0.001	6-Nov-17		
RCI Sampling Complete											
Rockwood	07-Jun-17	Flush	9:30-10:30								
Day 1	08-Jun-17	B. Roesler	8:32	S	7:02	Rm 3	S	3.0	30-Jun-17		
		we		F	7:53	Rm 3	F	<0.001	30-Jun-17		
	08-Jun-17	B. Roesler	8:33	S	7:03	Rm 4	S	3.0	30-Jun-17		
				F	7:53	Rm 4	F	<0.001	30-Jun-17		
	08-Jun-17	B. Roesler	8:34	S	7:04	Rm 5	S	2.0	30-Jun-17		
				F	7:54	Rm 5	F	<0.001	30-Jun-17		
	08-Jun-17	B. Roesler	8:35	S	7:05	Rm 6	S	2.0	30-Jun-17		
				F	7:54	Rm 6	F	<0.001	30-Jun-17		
	08-Jun-17	B. Roesler	8:36	S	7:06	Rm 7	S	2.0	30-Jun-17		
				F	7:55	Rm 7	F	<0.001	30-Jun-17		
	08-Jun-17	B. Roesler	8:37	S	7:07	Rm 8	S	2.0	30-Jun-17		
				F	7:55	Rm 8	F	<0.001	30-Jun-17		
Rockwood	07-Jun-17	Flush	9:30-10:30								
Day 2	09-Jun-17	B. Roesler	8:30	S	7:00	Rm 3 - Fountain	S	4.0	30-Jun-17		
				F	7:57	Rm 3 - Fountain	F	3.0	30-Jun-17		
	09-Jun-17	B. Roesler	8:31	S	7:01	Rm 4 - Fountain	S	6.0	30-Jun-17		
				F	7:57	Rm 4 - Fountain	F	3.0	30-Jun-17		
	09-Jun-17	B. Roesler	8:33	S	7:03	Rm 6 - Fountain	S	5.0	30-Jun-17		
				F	7:59	RM 6 - Fountain	F	2.0	30-Jun-17		
	09-Jun-17	B. Roesler	8:34	S	7:04	Rm 7 Fountain	S	10.0	5-Jul-17		
				F	8:00	Rm 7 Fountain	F	2.0	5-Jul-17		
	09-Jun-17	B. Roesler	8:35	S	7:05	Rm 8 Fountain	S	3.0	5-Jul-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
				F	8:01	Rm 8 Fountain	F	1.0	5-Jul-17		
Rockwood	12-Jun-17	Flush	9:30-10:30								
Day 3	13-Jun-17	B. Roesler	8:30	S	7:00	Rm 13 Tap 3 Kindergarten	S	<0.001	5-Jul-17		
				F	8:00	Rm 13 Tap 3 Kindergarten	F	<0.001	5-Jul-17		
	13-Jun-17	B. Roesler	8:31	S	7:01	Breakfast Club Tap 2	S	9.0	5-Jul-17		
				F	8:01	Breakfast Club Tap 2	F	3.0	5-Jul-17		
	13-Jun-17	B. Roesler	8:32	S	7:02	Rm 1 - Tap 3	S	1.0	5-Jul-17		
				F	8:05	Rm 1 Tap 3	F	<0.001	5-Jul-17		
	13-Jun-17	B. Roesler	8:32	S	7:02	Staff Kitchen, Tap 2	S	4.0	5-Jul-17		
				F	8:02	Staff Kitchen, Tap 2	F	1.0	5-Jul-17		
	13-Jun-17	B. Roesler	8:39	S	7:09	Room 10, Tap 1	S	5.0	5-Jul-17		
				F	8:03	Room 10, Tap 1	F	2.0	5-Jul-17		
	13-Jun-17	B. Roesler	8:43	S	7:13	Rm 2, Tap 3	S	2.0	5-Jul-17		
				F	8:06	Rm 2, Tap 3	F	<0.001	5-Jul-17		
	13-Jun-17	B. Roesler	8:35	S	7:05	Rm 5 Fountain	S	4.0	5-Jul-17		
				F	8:04	Rm 5 Fountain	F	2.0	5-Jul-17		
Rockwood	13-Jun-17	Flush	9:30-10:30								
Day 4	14-Jun-17	B. Roesler	8:05	S	6:35	Breakfast Club Tap 1	S	2.0	30-Jun-17		
				F	7:31	Breakfast Club Tap 1	F	<0.001	30-Jun-17		
	14-Jun-17	B. Roesler	8:04	S	6:34	Room 13- Tap 1	S	<0.001	30-Jun-17		
				F	7:34	Room 13- Tap 1	F	<0.001	30-Jun-17		
	14-Jun-17	B. Roesler	8:07	S	6:37	Rm 11	S	14.0	30-Jun-17	Daily Flushing while in service	Tap capped off Nov 10/17 No daily flushing required - NFA
				F	7:30	Rm 11	F	5.0	30-Jun-17		
	14-Jun-17	B. Roesler	8:08	S	6:38	Rm 1 Tap #1	S	<0.001	30-Jun-17		
				F	7:27	Rm 1 Tap #1	F	<0.001	30-Jun-17		
	14-Jun-17	B. Roesler	8:09	S	6:39	Rm 2 - Tap 1	S	1.0	30-Jun-17		
				F	7:30	Rm 2 - Tap 1	F	<0.001	30-Jun-17		
Rockwood	14-Jun-17	Flush	9:30-10:30								
Day 5	15-Jun-17	B. Roesler	8:37	S	7:07	Rm 2 - Tap 2	S	1.0	5-Jul-17		
				F	8:01	Rm 2 - Tap 2	F	1.0	5-Jul-17		
	15-Jun-17	B. Roesler	8:40	S	7:10	Rm 13	S	<0.001	30-Jun-17		
				F	8:05	Rm 13	F	1.0	30-Jun-17		
	15-Jun-17	B. Roesler	8:41	S	7:11	French Office	S	52.0	30-Jun-17	Out of Service & Investigate	Tap capped off - out of service NFA
				F	8:05	French Office	F	17.0	30-Jun-17		
	15-Jun-17	B. Roesler	8:42	S	7:12	Rm 19	S	2.0	30-Jun-17		
				F	8:06	Rm 19	F	1.0	30-Jun-17		
	15-Jun-17	B. Roesler	8:42	S	7:12	Rm 14	S	1.0	30-Jun-17		
				F	8:07	Rm 14	F	<0.001	30-Jun-17		
Rockwood	26-Jun-17	Flush	9:30-10:30								
Day 6	27-Jun-17	B. Roesler	8:37	S	7:07	Rm 15	S	8.0	14-Jul-17		
				F	7:58	Rm 15	F	3.0	14-Jul-17		
	27-Jun-17	B. Roesler	8:38	S	7:08	Rm 16	S	<0.001	17-Jul-17		
				F	7:58	Rm 16	F	<0.001	17-Jul-17		
	27-Jun-17	B. Roesler	8:39	S	7:09	Rm 17	S	<0.001	14-Jul-17		
				F	7:59	Rm 17	F	<0.001	14-Jul-17		
	27-Jun-17	B. Roesler	8:39	S	7:09	Rm 18	S	<0.001	14-Jul-17		
				F	7:59	Rm 18	F	<0.001	14-Jul-17		
	27-Jun-17	B. Roesler	8:41	S	7:11	Rm 22	S	5.0	17-Jul-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
				F	8:01	Rm 22	F	1.0	17-Jul-17		
Rockwood	28-Jun-17	Flush	9:30-10:30								
Day 7	29-Jun-17	B. Roesler	8:57	S	7:27	Fountain Main Hall	S	<0.001	11-Jul-17		
				F	8:25	Fountain Main Hall	F	<0.001	11-Jul-17		
	29-Jun-17	B. Roesler	8:59	S	7:29	Rm 9 Fountain	S	9.0	17-Jul-17	Retest - then Out of Service	Fountain Removed - NFA
				F	8:29	Rm 9 Fountain	F	22.0	17-Jul-17		
	29-Jun-17	B. Roesler	9:01	S	7:31	Kindergarten Fountain Hall	S	<0.001	14-Jul-17		
				F	8:19	Kindergarten Fountain Hall	F	<0.001	14-Jul-17		
	29-Jun-17	B. Roesler	8:55	S	7:25	Rm 21	S	2.0	14-Jul-17		
				F	8:28	Rm 21	F	<0.001	14-Jul-17		
Rockwood	25-Jul-17	Flush	9:30-10:30								
Day 8	26-Jul-17	B. Roesler	8:42	S	7:12	Rm 1 - Tap 2	S	2.0	2-Aug-17		
				F	8:06	Rm 1 - Tap 2	F	1.0	2-Aug-17		
	26-Jul-17	B. Roesler	8:45	S	7:15	Rm 9 Tap	S	7.0	2-Aug-17		
				F	8:04	Rm 9 Tap	F	3.0	2-Aug-17		
	26-Jul-17	B. Roesler	8:46	S	7:16	Staff Kitchen Tap 1	S	3.0	2-Aug-17		
				F	8:02	Staff Kitchen Tap 1	F	1.0	2-Aug-17		
Rockwood	26-Sep-17	Flush	9:30-10:30								
Day 9	27-Sep-17	B. Roesler	8:11	S	6:41	Room 20 tap	S	<0.001	3-Oct-17		
				F	7:37	Room 20 tap	F	<0.001	3-Oct-17		
	27-Sep-17	B. Roesler	8:15	S	6:45	Kindergarten fountain primary hall	S	<0.001	3-Oct-17		
				F	7:33	Kindergarten fountain primary hall	F	<0.001	3-Oct-17		
Rockwood - Sampling Complete											
Valour	14-Jun-17	Flush	14-Jun								
Day 1 - Valour	15-Jun-17	N. Godreau	6:16	S	5:30	Rm 106 - Tap 3	S	<0.001	6-Jul-17		
				F	6:19	Rm 106 - Tap 3	F	<0.001	6-Jul-17		
	15-Jun-17	N. Godreau	6:17	S	5:31	Rm 110 - Tap 3	S	<0.001	6-Jul-17		
				F	6:20	Rm 110 - Tap 3	F	<0.001	6-Jul-17		
Day 2 - Valour	19-Jun-17	Flush	19-Jun-17								
	20-Jun-17	N. Godreau	6:16	S	5:31	Caf Rm 101 Prep Sink	S	<0.001	10-Jul-17		
				F	6:20	Caf Rm 101 Prep Sink	F	<0.001	10-Jul-17		
	20-Jun-17	N. Godreau	6:17	S	5:32	Rm 114 - Tap 1	S	<0.001	10-Jul-17		
				F	6:17	Rm 114 - Tap 1	F	<0.001	10-Jul-17		
Day 3 - Valour	20-Jun-17	Flush	20-Jun								
	21-Jun-17	N. Godreau	6:16	S	5:30	Rm 190 - Tap 2	S	1.0	10-Jul-17		
				F	6:22	Rm 190 - Tap 2	F	<0.001	10-Jul-17		
	21-Jun-17	N. Godreau	6:16	S	5:30	Rm 190 - Tap 3	S	<0.001	10-Jul-17		
				F	6:22	Rm 190 - Tap 3	F	<0.001	10-Jul-17		
	21-Jun-17	N. Godreau	6:17	S	5:31	Fountain #1 - By Elementary	S	<0.001	10-Jul-17		
				F	6:21	Fountain #1 - By Elementary	F	<0.001	10-Jul-17		
	21-Jun-17	N. Godreau	6:20	S	5:34	Rm 114 - Tap 2	S	<0.001	10-Jul-17		
				F	6:19	Rm 114 Tap 2	F	<0.001	10-Jul-17		
Day 4 - Valour	21-Jun-17	Flush	21-Jun								
	22-Jun-17	N. Godreau	6:18	S	5:31	Rm 186	S	<0.001	10-Jul-17		
				F	6:24	Rm 186	F	<0.001	10-Jul-17		
	22-Jun-17	N. Godreau	6:19	S	5:32	Rm 114 - Tap 3	S	<0.001	10-Jul-17		
				F	6:23	Rm 114 - Tap 3	F	<0.001	10-Jul-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
	22-Jun-17	N. Godreau	6:23	S	5:36	Fountain # 1 – 1 st Floor by Change Room	S	<0.001	10-Jul-17		
				F	6:21	Fountain # 1 – 1 st Floor by Change Room	F	<0.001	10-Jul-17		
Day 5 - Valour	22-Jun-17	Flush	22-Jun								
	23-Jun-17	N. Godreau	6:16	S	5:30	Fountain by Caf Vending Machine	S	<0.001	10-Jul-17		
				F	6:25	Fountain by Caf Vending Machine	F	<0.001	10-Jul-17		
	23-Jun-17	N. Godreau	6:17	S	5:31	Rm 118	S	<0.001	10-Jul-17		
				F	6:24	Rm 118	F	<0.001	10-Jul-17		
Day 6 - Valour	12-Jul-17	Flush	12-Jul								
	13-Jul-17	N. Godreau	15:43	S	7:00	Rm 190 - Tap 4	S	<0.001	27-Jul-17		
				F	7:54	Rm 190 - Tap 4	F	<0.001	27-Jul-17		
	13-Jul-17	N. Godreau	15:44	S	7:01	Rm 120	S	<0.001	27-Jul-17		
				F	7:51	Rm 120	F	<0.001	27-Jul-17		
	13-Jul-17	N. Godreau	15:45	S	7:02	Rm 122	S	<0.001	27-Jul-17		
				F	7:52	Rm 122	F	<0.001	27-Jul-17		
	13-Jul-17	N. Godreau	15:46	S	7:04	Rm 116 - Tap 3	S	<0.001	27-Jul-17		
				F	7:49	Rm 116 - Tap 3	F	<0.001	27-Jul-17		
Day 7 - Valour	18-Jul-17	Flush	18-Jul								
	19-Jul-17	N. Godreau	15:40	S	7:00	Exercise Rm 135	S	1.0	27-Jul-17		
				F	7:54	Exercise Rm 135	F	<0.001	27-Jul-17		
	19-Jul-17	N. Godreau	15:41	S	7:01	Rm 190 Tap 1	S	2.0	27-Jul-17		
				F	7:51	Rm 190 Tap 1	F	<0.001	27-Jul-17		
	19-Jul-17	N. Godreau	15:42	S	7:02	Rm 190 Tap 5	S	<0.001	27-Jul-17		
				F	7:52	Rm 190 Tap 5	F	<0.001	27-Jul-17		
	19-Jul-17	N. Godreau	15:42	S	7:04	1st Flr Fountain #2 by elevator	S	<0.001	27-Jul-17		
				F	7:49	1st Flr Fountain #2 by elevator	F	<0.001	27-Jul-17		
Day 8 - Valour	19-Jul-17	Flush	19-Jul								
	20-Jul-17	N. Godreau	15:40	S	7:00	Rm 116 Tap 2	S	<0.001	27-Jul-17		
				F	7:49	Rm 116 Tap 2	F	<0.001	27-Jul-17		
	20-Jul-17	N. Godreau	15:41	S	7:01	Rm 110 Tap 2	S	<0.001	2-Aug-17		
				F	7:48	Rm 110 Tap 2	F	<0.001	2-Aug-17		
	20-Jul-17	N. Godreau	15:42	S	7:02	Rm 106 Tap 2	S	<0.001	2-Aug-17		
				F	7:47	Rm 106 Tap 2	F	<0.001	2-Aug-17		
Day 9 - Valour	24-Jul-17	Flush	24-Jul								
	25-Jul-17	N. Godreau	15:41	S	7:01	Rm 110 Tap 1	S	<0.001	2-Aug-17		
				F	7:48	Rm 110 Tap 1	F	<0.001	2-Aug-17		
	25-Jul-17	N. Godreau	15:42	S	7:02	Rm 106 Tap 1	S	<0.001	2-Aug-17		
				F	7:47	Rm 106 Tap 1	F	<0.001	2-Aug-17		
	25-Jul-17	N. Godreau	15:43	S	7:03	Rm 116 Tap 1	S	<0.001	2-Aug-17		
				F	7:49	Rm 116 Tap 1	F	<0.001	2-Aug-17		
Day 10 - Valour	25-Jul-17	Flush									
	26-Jul-17	N. Godreau	15:40	S	7:00	Fountain Outside Rm 226	S	<0.001	2-Aug-17		
				F	7:53	Fountain Outside Rm 226	F	<0.001	2-Aug-17		
	26-Jul-17	N. Godreau	15:42	S	7:02	Rm 220	S	<0.001	2-Aug-17		
				F	7:51	Rm 220	F	<0.001	2-Aug-17		
	26-Jul-17	N. Godreau	15:43	S	7:03	Rm 218	S	<0.001	2-Aug-17		
				F	7:50	Rm 218	F	<0.001	2-Aug-17		
	26-Jul-17	N. Godreau	15:44	S	7:04	Rm 216	S	<0.001	2-Aug-17		
				F	7:49	Rm 216	F	<0.001	2-Aug-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
Day 11 - Valour	25-Sep-17	Flush	25-Sep								
	26-Sep-17	N. Godreau	6:10	S	5:26	Fountain #1 Across Rm 182	S	<0.001	11-Oct-17		
				F	6:19	Fountain #1 Across Rm 182	F	<0.001	11-Oct-17		
	26-Sep-17	N. Godreau	6:12	S	5:28	Fountain #1 (Outside HS change room)	S	<0.001	11-Oct-17		
				F	6:17	Fountain #1 (Outside HS change room)	F	<0.001	11-Oct-17		
Day 12 - Valour	26-Sep-17	Flush	26-Sep								
	27-Sep-17	N. Godreau	6:06	S	5:22	Fountain # 2 Across Rm 182	S	<0.001	11-Oct-17		
				F	6:14	Fountain # 2 Across Rm 182	F	<0.001	11-Oct-17		
	27-Sep-17	N. Godreau	6:08	S	5:24	Fountain #2 (Outside HS change room)	S	<0.001	11-Oct-17		
				F	6:12	Fountain #2 (Outside HS change room)	F	<0.001	11-Oct-17		
	27-Sep-17	N. Godreau	6:10	S	5:26	Rm 174A	S	<0.001	11-Oct-17		
				F	6:11	Rm 174A	F	<0.001	11-Oct-17		
Day 13 - Valour	27-Sep-17	Flush	27-Sep								
	28-Sep-17	N. Godreau	6:09	S	5:25	Classroom 142 tap	S	<0.001	11-Oct-17		
				F	6:14	Classroom 142 tap	F	<0.001	11-Oct-17		
	28-Sep-17	N. Godreau	6:10	S	5:26	Classroom 140 tap	S	<0.001	11-Oct-17		
				F	6:13	Classroom 140 tap	F	<0.001	11-Oct-17		
	28-Sep-17	N. Godreau	6:11	S	5:27	Classroom 138 tap	S	<0.001	11-Oct-17		
				F	6:12	Classroom 138 tap	F	<0.001	11-Oct-17		
	28-Sep-17	N. Godreau	6:07	S	5:23	Classroom 146	S	<0.001	19-Oct-17		
				F	6:16	Classroom 146	F	<0.001	19-Oct-17		
	28-Sep-17	N. Godreau	6:08	S	5:24	Classroom 144	S	<0.001	19-Oct-17		
				F	6:15	Classroom 144	F	<0.001	19-Oct-17		
Day 15 - Valour	28-Sep-17	Flush	28-Sep								
	29-Sep-17	N. Godreau	6:03	S	5:13	Fountain # 2 Outside Elem Change Rm	S	<0.001	19-Oct-17		
				F	6:03	Fountain # 2 Outside Elem Change Rm	F	<0.001	19-Oct-17		
	29-Sep-17	N. Godreau	6:05	S	5:15	Classroom 128	S	<0.001	19-Oct-17		
				F	6:02	Classroom 128	F	<0.001	19-Oct-17		
	29-Sep-17	N. Godreau	6:06	S	5:16	Staffroom Rm 136 tap	S	<0.001	19-Oct-17		
				F	6:01	Staffroom Rm 136 tap	F	<0.001	19-Oct-17		
Day 16 - Valour	02-Oct-17	Flush	02-Oct								
	03-Oct-17	N. Godreau	6:09	S	5:20	Fountain #1 Across Rm 258 (2nd Floor)	S	<0.001	23-Oct-17		
				F	6:13	Fountain #1 Across Rm 258 (2nd Floor)	F	<0.001	23-Oct-17		
	03-Oct-17	N. Godreau	6:11	S	5:22	Classroom 268 Tap	S	<0.001	24-Oct-17		
				F	6:11	Classroom 268 Tap	F	<0.001	24-Oct-17		
	03-Oct-17	N. Godreau	6:13	S	5:24	2nd Flr Fountain #1 by Elevator	S	<0.001	24-Oct-17		
				F	6:09	2nd Flr Fountain #1 by Elevator	F	<0.001	24-Oct-17		
Day 17 - Valour	03-Oct-17	Flush	03-Oct								
	04-Oct-17	N. Godreau	6:08	S	5:20	Fountain #2 Across Rm 258 (2nd Floor)	S	<0.001	24-Oct-17		
				F	6:14	Fountain #2 Across Rm 258 (2nd Floor)	F	<0.001	24-Oct-17		
	04-Oct-17	N. Godreau	6:10	S	5:22	Room 270 Tap	S	<0.001	6-Nov-17		
				F	6:13	Room 270 Tap	F	<0.001	6-Nov-17		
	04-Oct-17	N. Godreau	6:11	S	5:23	Fountain #2 by Elevator upstairs	S	<0.001	6-Nov-17		
				F	6:11	Fountain #2 by Elevator upstairs	F	<0.001	6-Nov-17		
	04-Oct-17	N. Godreau	6:13	S	5:25	Room 200 Tap	S	<0.001	6-Nov-17		
				F	6:10	Room 200 Tap	F	<0.001	6-Nov-17		
Day 18 - Valour	04-Oct-17	Flush	04-Oct								
	05-Oct-17	N. Godreau	6:05	S	5:17	Room 202 Tap	S	<0.001	6-Nov-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
				F	6:10	Room 202 Tap	F	<0.001	6-Nov-17		
	05-Oct-17	N. Godreau	6:06	S	5:18	Room 204 Tap	S	<0.001	6-Nov-17		
				F	6:09	Room 204 Tap	F	<0.001	6-Nov-17		
	05-Oct-17	N. Godreau	6:07	S	5:19	Room 206 Tap	S	<0.001	6-Nov-17		
				F	6:08	Room 206 Tap	F	<0.001	6-Nov-17		
	05-Oct-17	N. Godreau	6:08	S	5:20	Rm 208 Tap	S	<0.001	6-Nov-17		
				F	6:07	Rm 208 Tap	F	<0.001	6-Nov-17		
	05-Oct-17	N. Godreau	6:09	S	5:21	Rm 210 Tap	S	<0.001	6-Nov-17		
				F	6:06	Rm 210 Tap	F	<0.001	6-Nov-17		
Day 19 - Valour	05-Oct-17	Flush	05-Oct								
	06-Oct-17	N. Godreau	6:09	S	5:20	Room 216 Tap	S	<0.001	6-Nov-17		
				F	6:15	Room 216 Tap	F	<0.001	6-Nov-17		
	06-Oct-17	N. Godreau	6:10	S	5:21	Rm 218 Tap	S	<0.001	6-Nov-17		
				F	5:14	Rm 218 Tap	F	<0.001	6-Nov-17		
	06-Oct-17	N. Godreau	6:11	S	5:22	Rm 220 Tap	S	<0.001	6-Nov-17		
				F	6:13	Rm 220 Tap	F	<0.001	6-Nov-17		
	06-Oct-17	N. Godreau	6:12	S	5:23	Rm 222 Tap	S	<0.001	6-Nov-17		
				F	6:12	Rm 222 Tap	F	<0.001	6-Nov-17		
	06-Oct-17	N. Godreau	6:13	S	5:24	Fountain Outside Rm 226	S	<0.001	6-Nov-17		
				F	6:10	Fountain Outside Rm 226	F	<0.001	6-Nov-17		
Day 21 - Valour	10-Oct-17	Flush	10-Oct								
	11-Oct-17	N. Godreau	6:10	S	5:20	Rm 224 Tap	S	<0.001	6-Nov-17		
				F	6:11	Rm 224 Tap	F	<0.001	6-Nov-17		
	11-Oct-17	N. Godreau	6:11	S	5:21	Rm 226 Tap	S	<0.001	6-Nov-17		
				F	6:10	Rm 226 Tap	F	<0.001	6-Nov-17		
	11-Oct-17	N. Godreau	6:12	S	5:22	Rm 234 Tap	S	<0.001	6-Nov-17		
				F	6:09	Rm 234 Tap	F	<0.001	6-Nov-17		
	11-Oct-17	N. Godreau	6:13	S	5:23	Rm 244 Tap	S	<0.001	6-Nov-17		
				F	6:08	Rm 244 Tap	F	<0.001	6-Nov-17		
Day 20 - Valour	11-Oct-17	Flush	11-Oct								
	12-Oct-17	N. Godreau	6:11	S	5:21	Rm 238 Tap	S	<0.001	23-Oct-17		
				F	6:10	Rm 238 Tap	F	<0.001	23-Oct-17		
	12-Oct-17	N. Godreau	6:12	S	5:22	Rm 240 Tap	S	<0.001	23-Oct-17		
				F	6:09	Rm 240 Tap	F	<0.001	23-Oct-17		
	12-Oct-17	N. Godreau	6:13	S	5:23	Rm 242 Tap	S	<0.001	23-Oct-17		
				F	6:08	Rm 242 Tap	F	<0.001	23-Oct-17		
	12-Oct-17	N. Godreau	6:10	S	5:20	Rm 236 Tap	S	<0.001	6-Nov-17		
				F	6:11	Rm 236 Tap	F	<0.001	6-Nov-17		
Valour Sampling Complete											
Walter Zadow	06-Jun-17	Flush	9:45-10:45								
Day 1	07-Jun-17	J. Hartwick	6:15	S	5:00	Kitchen	S	10.0	27-Jun-17		
				F	5:54	Kitchen	F	4.0	27-Jun-17		
	07-Jun-17	J. Hartwick	6:16	S	5:01	Rm 5	S	5.0	27-Jun-17		
				F	5:55	Rm 5	F	2.0	27-Jun-17		
	07-Jun-17	J. Hartwick	6:17	S	5:02	Rm 3	S	2.0	27-Jun-17		
				F	5:56	Rm 3	F	1.0	27-Jun-17		
	07-Jun-17	J. Hartwick	6:18	S	5:03	Rm 1	S	3.0	27-Jun-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
				F	5:57	Rm 1	F	1.0	27-Jun-17		
	07-Jun-17	J. Hartwick	6:19	S	5:04	Rm 18	S	3.0	27-Jun-17		
				F	5:58	Rm 18	F	1.0	27-Jun-17		
	07-Jun-17	J. Hartwick	6:20	S	5:05	Rm 16	S	4.0	27-Jun-17		
				F	5:59	Rm 16	F	1.0	27-Jun-17		
	07-Jun-17	J. Hartwick	6:22	S	5:07	Rm 22 - Tap 1	S	8.0	27-Jun-17		
				F	6:01	Rm 22 - Tap 1	F	2.0	27-Jun-17		
Walter Zadow	12-Jun-17	Flush	9:45-10:45								
Day 2	13-Jun-17	J. Hartwick	6:15	S	5:00	Rm 21 - Tap 1	S	3.0	27-Jun-17		
				F	5:55	Rm 21 - Tap 1	F	2.0	27-Jun-17		
	13-Jun-17	J. Hartwick	6:16	S	5:01	Rm 23 - Tap 1	S	2.0	27-Jun-17		
				F	5:56	Rm 23 - Tap 1	F	2.0	27-Jun-17		
	13-Jun-17	J. Hartwick	6:17	S	5:02	Rm 4	S	2.0	27-Jun-17		
				F	5:57	Rm 4	F	<0.001	27-Jun-17		
	13-Jun-17	J. Hartwick	6:18	S	5:03	Staffroom	S	<0.001	27-Jun-17		
				F	5:58	Staffroom	F	<0.001	27-Jun-17		
	13-Jun-17	J. Hartwick	6:19	S	5:04	Rm 15	S	3.0	27-Jun-17		
				F	5:59	Rm 15	F	1.0	27-Jun-17		
	13-Jun-17	J. Hartwick	6:20	S	5:05	Rm 17	S	4.0	27-Jun-17		
				F	6:00	Rm 17	F	1.0	27-Jun-17		
	13-Jun-17	J. Hartwick	6:22	S	5:07	Piano Rm basement	S	26.0	23-Jun-17	Daily Flush - Resample	Resampled July 18/17
				F	6:02	Piano Rm basement	F	10.0	23-Jun-17		Resolved
Walter Zadow	13-Jun-17	Flush	9:45-10:45								
Day 4	14-Jun-17	J. Hartwick	6:15	S	5:00	Rm 6	S	26.0	23-Jun-17	Daily Flush	Daily flush of tap
				F	5:53	Rm 6	F	5.0	23-Jun-17		
	14-Jun-17	J. Hartwick	6:16	S	5:01	Rm 8	S	32.0	23-Jun-17	Daily Flush	Daily flush of tap
				F	5:54	Rm 8	F	1.0	23-Jun-17		
	14-Jun-17	J. Hartwick	6:17	S	5:02	Rm 29	S	33.0	23-Jun-17	Daily Flush	Daily flush of tap
				F	5:55	Rm 29	F	3.0	23-Jun-17		
	14-Jun-17	J. Hartwick	6:18	S	5:03	Rm 11	S	3.0	27-Jun-17		
				F	5:56	Rm 11	F	1.0	27-Jun-17		
Walter Zadow	17-Jul-17	Flush	9:45-10:45								
Day 5	18-Jul-17	J. Hartwick	6:15	S	6:00	Piano Room - Resample	S	5.0	2-Aug-17	Resolved	Resolved - NFA
				F	6:45	Piano Room - Resample	F	3.0	2-Aug-17		
Walter Zadow	05-Oct-17	Flush	9:45-10:45								
Day 6	06-Oct-17	B. MacLean	7:10	S	5:55	Rm 23 Tap 2	S	2.0	25-Oct-17		
				F	6:01	Rm 23 Tap 2	F	4.0	25-Oct-17		
	06-Oct-17	B. MacLean	7:11	S	5:56	Rm 22 Tap 2	S	2.0	25-Oct-17		
				F	6:46	Rm 22 Tap 2	F	2.0	25-Oct-17		
	06-Oct-17	B. MacLean	7:13	S	5:58	Rm 21 Tap 2	S	2.0	25-Oct-17		
				F	6:47	Rm 21 Tap 2	F	2.0	25-Oct-17		
Walter Zadow	12-Oct-17	Flush	10-11:00								
Day 7	13-Oct-17	B. MacLean	6:30	S	5:30	Rm 23 Fountain	S	2.0	25-Oct-17		
				F	6:27	Rm 23 Fountain	F	1.0	25-Oct-17		
	13-Oct-17	B. MacLean	6:30	S	5:30	Rm 22 Fountain	S	4.0	25-Oct-17		
				F	6:27	Rm 22 Fountain	F	3.0	25-Oct-17		
	13-Oct-17	B. MacLean	6:32	S	5:32	Rm 21 Fountain	S	2.0	25-Oct-17		
				F	6:30	Rm 21 Fountain	F	2.0	25-Oct-17		

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
	13-Oct-17	B. MacLean	6:34	S	5:34	Fountain by Rm 3	S	<0.001	25-Oct-17		
				F	6:30	Fountain by Rm 3	F	<0.001	25-Oct-17		
Walter Zadow	16-Oct-17	Flush	9:52-10:52								
Day 8	17-Oct-17	B. MacLean	6:43	S	5:35	Rm 12 Tap	S	8.0	25-Oct-17		
				F	6:27	Rm 12 Tap	F	3.0	25-Oct-17		
	17-Oct-17	B. MacLean	6:43	S	5:35	Rm 13 Tap	S	7.0	25-Oct-17		
				F	6:27	Rm 13 Tap	F	6.0	25-Oct-17		
	17-Oct-17	B. MacLean	6:48	S	5:40	Fountain by Rm 15	S	<0.001	25-Oct-17		
				F	6:35	Fountain by Rm 15	F	<0.001	25-Oct-17		
	17-Oct-17	B. MacLean	6:44	S	5:36	Rm 14 Tap	S	3.0	25-Oct-17		
				F	6:28	Rm 14 Tap	F	2.0	25-Oct-17		
Walter Zadow	17-Oct-17	Flush	9:45-10:45								
Day 9	18-Oct-17	B. MacLean	6:47	S	5:32	Rm 7 Tap	S	3.0	24-Oct-17	Out of Service & Investigate	Worker Order to Change tap
				F	6:23	Rm 7 Tap	F	15.0	24-Oct-17		
	18-Oct-17	B. MacLean	6:50	S	5:35	Rm 9 Tap	S	155.0	24-Oct-17	Out of Service & Investigate	Work Order to Change Tap
				F	6:23	Rm 9 Tap	F	140.0	24-Oct-17		
	18-Oct-17	B. MacLean	6:50	S	5:35	Rm 10 Tap	S	3.0	25-Oct-17		
				F	6:23	Rm 10 Tap	F	2.0	25-Oct-17		
	18-Oct-17	B. MacLean	6:51	S	5:36	Fountain by Rm 8	S	<0.001	25-Oct-17		
				F	6:26	Fountain by Rm 8	F	<0.001	25-Oct-17		
Walter Zadow - Sampling Complete											
Mary St. Ed. Centre	05-Jun-17	Flush	05-Jun								
Day 1	06-Jun-17	J. Letourneau	15:05	S	6:50	Rm 113A Kitchen	S	2.0	6-Jul-17		
				F	7:35	Rm 113A Kitchen	F	<0.001	6-Jul-17		
Day 2	07-Jun-17	Flush	07-Jun-17								
	08-Jun-17	J. Letourneau	13:44	S	6:32	Rm 18A Kitchen	S	9.0	6-Jul-17		
				F	7:17	Rm 18A Kitchen	F	3.0	6-Jul-17		
	08-Jun-17	J. Letourneau	13:46	S	6:35	Hall 17 Fountain	S	<0.001	4-Jul-17		
				F	7:20	Hall 17 Fountain	F	<0.001	4-Jul-17		
	08-Jun-17	J. Letourneau	13:46	S	6:36	Classroom 27	S	4.0	5-Jul-17		
				F	7:21	Classroom 27	F	1.0	5-Jul-17		
	08-Jun-17	J. Letourneau	13:48	S	6:37	Classroom 28	S	30.0	4-Jul-17	Daily Flush	Daily flush of tap
				F	7:22	Classroom 28	F	2.0	4-Jul-17		
Day 3	12-Jun-17	Flush	12-Jun-17								
	13-Jun-17	J. Letourneau	13:43	S	6:33	Rm 10B Kitchen	S	14.0	4-Jul-17	Daily Flush	Daily flush of tap
				F	7:18	Rm 10B Kitchen	F	3.0	4-Jul-17		
	13-Jun-17	J. Letourneau	13:44	S	6:35	Rm 002 Fountain	S	4.0	5-Jul-17		
				F	7:20	Rm 002 Fountain	F	4.0	5-Jul-17		
	13-Jun-17	J. Letourneau	13:44	S	6:37	Rm 211 Staff Kitchen	S	1.0	5-Jul-17		
				F	7:22	Rm 211 Staff Kitchen	F	<0.001	5-Jul-17		
Day 4	19-Jun-17	Flush	19-Jun								
	20-Jun-17	J. Letourneau	14:52	S	6:42	Hall 102 Fountain	S	<0.001	10-Jul-17		
				F	7:27	Hall 102 Fountain	F	<0.001	10-Jul-17		
	20-Jun-17	J. Letourneau	14:55	S	6:45	Hall 202 Fountain	S	<0.001	10-Jul-17		
				F	7:30	Hall 202 Fountain	F	<0.001	10-Jul-17		
Mary St. Sampling Complete											

2017 Lead Testing Results											
School	Date	Sample Taken By:	Estimate of Standing Period hh:mm	Sample	Time	Sample Area	Sample	Results mg/L	Date Results Rec'd	Follow-up Action as per PHI	Corrective Action
Whitney PS	NO SAMPLING FOR 2017 - Site Closing June 30, 2017					Moved locations to RCCDSB building - requested sample results from RCCDSB					