



| 2016 Lead Testing Results   |   |                  |                                   |        |      |                   |        |              |                    |                                |  |                       |
|-----------------------------|---|------------------|-----------------------------------|--------|------|-------------------|--------|--------------|--------------------|--------------------------------|--|-----------------------|
| School                      | Date  | Sample Taken By: | Estimate of Standing Period hh:mm | Sample | Time | Sample Area       | Sample | Results mg/L | Date Results Rec'd | Follow-up Action as per PHI    | In addition to this years results the following sites continue flushing until results clear 2 conseq years | Year adverse detected |
|                             | 14-Jun-16   | S. Michaud       | 6:15                              | S      | 5:35 | Kitchen           | S      | <0.001       | 24-Jun-16          | N/A                            |  |                       |
|                             | 14-Jun-16   | S. Michaud       |                                   | F      | 6:20 | Kitchen           | F      | <0.001       | 24-Jun-16          |                                |  |                       |
| <b>McNab</b>                | 21-Jun-16   | Preflush         | 7:55-8:55                         |        |      |                   |        |              |                    |                                |  |                       |
|                             | 22-Jun-16   | D. McNulty       | 9:25                              | S      | 6:20 | Rm 145C           | S      | 0.002        | 24-Jun-16          | N/A                            |  |                       |
|                             | 22-Jun-16   | D. McNulty       |                                   | F      | 7:05 | Rm 145C           | F      | 0.002        | 24-Jun-16          |                                |  |                       |
| <b>Opeongo HS</b>           | 14-Jun-16   | Preflush         | 10:00-11:00                       |        |      |                   |        |              |                    |                                |  |                       |
|                             | 15-Jun-16   | M. Lippert       | 7:00                              | S      | 6:00 | Cafeteria Kitchen | S      | 0.003        | 22-Jun-16          | N/A                            |  | 2012                  |
|                             | 15-Jun-16   | M. Lippert       |                                   | F      | 6:50 | Cafeteria Kitchen | F      | <0.001       | 22-Jun-16          |                                |  |                       |
| <b>Palmer Rapids</b>        | 15-Jun-16   | Preflush         | 3:20-4:25                         |        |      |                   |        |              |                    |                                |  |                       |
|                             | 16-Jun-16   | F. Welk          | 14:55                             | S      | 7:20 | Staff Rm          | S      | <0.001       | 24-Jun-16          | N/A                            |  |                       |
|                             | 16-Jun-16   | F. Welk          |                                   | F      | 8:06 | Staff Rm          | F      | <0.001       | 24-Jun-16          |                                |  |                       |
| <b>Pine View</b>            | 27-Jun-16   | Pre-flush        | 2:00-4:30                         |        |      |                   |        |              |                    |                                | Reduce to weekly flushing 2016-2 conseq years  | 2011-12-13-14         |
|                             | 28-Jun-16   | D. Goldberg      | 14:03                             | S      | 6:33 | Rm 118            | S      | 0.009        | 6-Jul-16           | Decrease to weekly             |  |                       |
|                             | 28-Jun-16   | D. Goldberg      |                                   | F      | 7:19 | Rm 118            | F      | 0.004        | 6-Jul-16           |                                |  |                       |
| <b>Queen Elizabeth</b>      | 13-Jun-16   | Preflush         | 6:55-7:55                         |        |      |                   |        |              |                    |                                |  |                       |
|                             | 14-Jun-16   | V. Verdon        | 10:07                             | S      | 6:02 | Kitchen           | S      | 0.004        | 24-Jun-16          | N/A                            |  |                       |
|                             | 14-Jun-16   | V. Verdon        |                                   | F      | 6:48 | Kitchen           | F      | 0.001        | 24-Jun-16          |                                |  |                       |
| <b>Renfrew Collegiate</b>   | 14-Jun-16   | Preflush         | 10-11:00                          |        |      |                   |        |              |                    |                                |  |                       |
|                             | 15-Jun-16   | B. Code          | 6:45                              | S      | 5:45 | Café Kitchen      | S      | 0.003        | 22-Jun-16          | N/A                            |  |                       |
|                             | 15-Jun-16   | B. Code          |                                   | F      | 6:30 | Café Kitchen      | F      | 0.001        | 22-Jun-16          |                                |  |                       |
| <b>Rockwood</b>             | 14-Jun-16   | Preflush         | 9:55-10:55                        |        |      |                   |        |              |                    |                                |  |                       |
|                             | 15-Jun-16   | B. Roesler       | 7:56                              | S      | 6:51 | Kitchen           | S      | 0.002        | 22-Jun-16          | N/A                            |  |                       |
|                             | 15-Jun-16   | B. Roesler       |                                   | F      | 7:38 | Kitchen           | F      | 0.001        | 22-Jun-16          |                                |  |                       |
| <b>Sherwood</b>             | NO SAMPLING FOR 2016 - Site Closing June 30, 2016 |                  |                                   |        |      |                   |        |              |                    |                                |  |                       |
| <b>Valour</b>               | 23-Jun-16   | Preflush         | 10:26-11:26                       |        |      |                   |        |              |                    |                                |  |                       |
|                             | 24-Jun-16   | B. Schauer       | 6:12                              | S      | 5:35 | Kitchen Rm 109    | S      | 0.002        | 6-Jul-16           | N/A                            |  |                       |
|                             | 24-Jun-16   | B. Schauer       |                                   | F      | 6:21 | Kitchen Rm 109    | F      | <0.001       | 6-Jul-16           |                                |  |                       |
| <b>Walter Zadow</b>         | 14-Jun-16   | Pre-flush        | 9:55-10:55                        |        |      |                   |        |              |                    |                                | Daily Flushing   | 2010/11/12/13/14/15   |
|                             | 15-Jun-16   | B. MacLean       | 7:35                              | S      | 6:30 | Kitchen Rm 127    | S      | 0.014        | 24-Jun-16          | Continue daily flushing        |  |                       |
|                             | 15-Jun-16   | B. MacLean       |                                   | F      | 7:15 | Kitchen Rm 127    | F      | 0.007        | 24-Jun-16          |                                |  |                       |
| <b>Westmeath</b>            | NO SAMPLING FOR 2016 - Site Closing June 30, 2016 |                  |                                   |        |      |                   |        |              |                    |                                |  |                       |
| <b>Whitney PS</b>           | 15-Jun-16   | Pre-flush        | 3:45-4:45                         |        |      |                   |        |              |                    |                                |  |                       |
|                             | 16-Jun-16   | B. Lynch         | 14:20                             | S      | 7:05 | Kitchen           | S      | 0.002        | 24-Jun-16          |                                |  |                       |
|                             | 16-Jun-16   | B. Lynch         |                                   | F      | 7:50 | Kitchen           | F      | <0.001       | 24-Jun-16          |                                |  |                       |
| <b>New Horizons</b>         | NO SAMPLING - Located at Champlain DPS            |                  |                                   |        |      |                   |        |              |                    |                                |  |                       |
| <b>Renfrew Con't Ed</b>     | 14-Jun-16   | Pre-flush        | 2:55-3:55                         |        |      |                   |        |              |                    |                                | Site closure June 2014   |                       |
|                             | 15-Jun-16   | B. Gauthier      | 15:05                             | S      | 7:00 | Kitchen           | S      | <0.001       | 24-Jun-16          |                                |  |                       |
|                             | 15-Jun-16   | B. Gauthier      |                                   | F      | 7:47 | Kitchen           | F      | <0.001       | 24-Jun-16          |                                |  |                       |
| <b>Arnprior Con't Ed</b>    | No Sampling - Located at ADHS                     |                  |                                   |        |      |                   |        |              |                    |                                |  |                       |
| <b>Petawawa Con't Ed</b>    | No Sampling Req'd                                 |                  |                                   |        |      |                   |        |              |                    |                                |  |                       |
| <b>Arnprior PAL</b>         | No Sampling - Moving into ADHS Sept 2016          |                  |                                   |        |      |                   |        |              |                    |                                |  |                       |
| <b>Barry's Bay PAL site</b> | 14-Jun-16   | Pre-flush        | 2:30-3:30                         |        |      |                   |        |              |                    |                                | Reduce to weekly flushing 2016-2 conseq years  | 2011<br>2014          |
|                             | 15-Jun-16   | S. Michaud       | 13:22                             | S      | 4:52 | Kitchen           | S      | 0.007        | 24-Jun-16          | Decrease to weekly             |  |                       |
|                             | 15-Jun-16   | S. Michaud       |                                   | F      | 5:40 | Kitchen           | F      | 0.001        | 24-Jun-16          |                                |  |                       |
| <b>Mary St. Ed. Centre</b>  | 08-Jun-16   | Pre-flush        | 3:45-4:55                         |        |      |                   |        |              |                    |                                |  | 2011                  |
|                             | 09-Jun-16   | J. Letourneau    | 12:39                             | S      | 6:34 | Kitchen Rm 113A   | S      | 0.003        | 24-Jun-16          | Continue daily flushing due to | Daily Flushing   | 2015                  |
|                             | 09-Jun-16   | J. Letourneau    |                                   | F      | 7:21 | Kitchen Rm 113A   | F      | 0.003        | 24-Jun-16          | 2015 results                   |  |                       |