MADAWASKA PUBLIC SCHOOL
WELL-WATER REPORT 2015-2016

Waterworks Number - 260014989

Sample Matrix - Drinking Water

RESULTS

Collection Date	Area Tested	Total Coliform	E coli	HPC	Nitrite	Nitrate	Sodium	Fluoride	AWQI #	Resolved	Date Resolved
		cts/100 mL	cts/100 mL	cfu/mL	mg/L	mg/L					
01-Sep-15	Kitchen - Distribution	0	0								
01-Sep-15	Pump Rm - Raw	0	0								
01-Sep-15	Pump Rm - Treated				<0.10	<0.10					
06-Oct-15	Kitchen - Distribution	0	0								
06-Oct-15	Pump Rm - Raw	0	0								
03-Nov-15	Kitchen - Distribution	0	0								
03-Nov-15	Pump Rm - Raw	0	0								
01-Dec-15	Kitchen - Distribution	0	0								
01-Dec-15	Pump Rm - Raw	0	0								
01-Dec-15	Pump Rm - Treated				<0.10	0.10					
05-Jan-16	Kitchen - Distribution	0	0								
05-Jan-16	Pump Room - Raw	0	0								
02-Feb-16	Kitchen - Distribution	0	0								
02-Feb-16	Pump Room - Raw	0	0								
03-Mar-16	Kitchen - Distribution	0	0								
03-Mar-16	Pump Room - Raw	0	0								
03-Mar-16	Pump Rm - Treated				<0.10	<0.10					
05-Apr-16	Kitchen - Distribution										
05-Apr-16	Pump Rm - Raw										
03-May-16	Kitchen - Distribution	0	0								
03-May-16	Pump Room - Raw	0	0								
07-Jun-16	Kitchen - Distribution	0	0								
07-Jun-16	Pump Rm - Raw	0	0								
07-Jun-16	Pump Rm - Treated				<0.10	0.26					
07-Jun-16	Kitchen - Treated						15	0.51			
July	Site Closure - Relocated to MVDHS										